



47 Hudson Street, Ossining, New York 10562
Tel: (914)-762-9000 • Fax: (914)-762-9638 • testwellabs.com

October 7, 2002

Offices in

Albany, NY
Queens, NY
Woodbridge, NJ
Miami, FL

Michael Deane, Project Manager
Bovis Lend Lease LMB
200 Park Avenue
New York, New York 10166

Certifications & Accreditations

Telephone: **212-592-6912**
Facsimile: **212-592-6988**

Regarding: **Millennium Hilton Hotel**
55 Church Street, New York, NY
Microvac Sampling at PBX Equipment



Dear Mr. Deane,

With regard to Microvac sampling that was performed at the PBX telephone equipment located on the 6th floor, please note that this method of analysis is highly sensitive and the mere presence of asbestos fibers does not represent that the surface sampled is contaminated. Background asbestos fiber concentrations may range from 3,000 to 5,000 asbestos structures per square centimeter.

None of the results for samples collected at the site indicate fiber concentrations at or above these levels.

If you have any questions or need additional information, please feel free to contact me at (914) 944-2563.

Respectfully,

Testwell Laboratories, Inc.


Charles Schnugg
Vice President

Cc: S. Flynn/BLL (212) 566-1437



NYS DOH ELAP #10871.
11142 & 11651



Testwell Laboratories, Inc.
Ossining, NY is accredited
by the American Industrial
Hygiene Association (AIHA)
in the industrial hygiene program
CERT NO. 100147