



ASBESTOS ANALYTICAL REPORT

ASBESTOS CONTROL PROGRAM LABORATORY
96-05 HORACE HARDING EXPRESSWAY
CORONA, NEW YORK 11368
(718) 595-6309 FAX# (718) 595-6307

ELAP # 11045

TEST METHODS: 1) 40 CFR Part 763, Subpart F, App. A
2) Polarized Light Microscopy plus Stratified Point-Counting Method
3) EPA/600/R-93/116

Incident #: 357634-A
 Inspector : C. LUTCHMEDIAL
 Premise : 55 LIBERTY STREET
 Boro : Manhattan
 Analyst : G. ANAKHU

Date Collected: 12/18/01
 Received: 12/18/01
 Analyzed: 12/18/01

Client #:

DEP Sample #: 11218/A058001

Laboratory #: 11218/868

Location Sampled: CURB

Color: BLACK

Homogenous: Yes

Asbestos Present: No

Results (%)

Cellulose	1
Silicates	50
Matrix	49

Comments:

Reviewed by: *R. A. Delaney*
 Laboratory Director

This test report may not be reproduced except with the written approval of this laboratory. The test report relates only to the item(s) listed and does not represent a product endorsement by NVLAP or any other U.S. Government agency.