NYC 9/11 Public Portal Document

ATC Associates
104 East 25 Street, New York, NY 10010
Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Fabio Pedone
Warren & Panzer Engineers , P.C.
228 E. 45th Street
New York NY 10017
Fax: (212) 922-0630 **Phone:** (212) 922-0077
Project: NYC-DEP W & P File # 1079.01.02
86 Nassau Street

Received: 7/3/02 8:00:00 AM
ATC Group #: 8386
Analysis Date: 7/3/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5	# Structures 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
03 8386 -1	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049	
04 8386 -2	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049	
05 8386 -3	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049	
06 8386 -4	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049	
07 8386 -5	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049	

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101157-0, NY State ELAP #10679

CITY_21MC100_002841490

NYC-WTC_000209566