

DEP**ASBESTOS ANALYTICAL REPORT**

**ASBESTOS CONTROL PROGRAM LABORATORY
96-05 HORACE HARDING EXPRESSWAY
CORONA, NEW YORK 11368
(718) 595-6309 FAX# (718) 595-6307**

ELAP # 11045

**TEST METHODS : 1) 40 CFR Part 763, Subpart F, App. A
2) Polarized Light Microscopy plus Stratified Point-Counting Method
3) EPA/600/R-93/116**

Incident #: WTC122302
Inspector : R. RAMMOHAN
Premise : 139 FULTON STREET
Boro : Manhattan
Analyst : G. FRUCHTMAN

Date Collected: 12/23/02
Received: 12/23/02
Analyzed: 12/26/02

Client #:

DEP Sample #:	21223/A078021	21223/A078022	21223/A078024
Laboratory #:	21223/139	21223/140	21223/142
Location Sampled:	307 E. WINDOW	213 EAST WINDOW	SHUTTER TOP
Color:	GREY	GREY	GREY
Homogenous:	Yes	Yes	Yes
Asbestos Present:	Yes	Yes	Yes

Results (%)

Chrysotile	trace	Chrysotile	<1	Chrysotile	<1
Cellulose	1	Cellulose	2	Cellulose	2
Fibrous glass	57	Fibrous glass	49	Fibrous glass	48
Matrix	42	Matrix	49	Other	trace
				Matrix	50

Comments:**Reviewed by:**
Laboratory Director

This test report may not be reproduced except with the written approval of this laboratory. The test report relates only to the item(s) listed and does not represent a product endorsement by NVLAP or any other U.S. Government agency.