

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email:

EMSLAttn: Victor Escalona
Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117

Phone: 718-792-2832

Project: Building 1 80 North Moore Street NY NY

Customer ID: COMM56

Customer PO:

Received: 10/31/01 1:26 PM

EMSL Order: 030107228


EMSL Project ID:

Analysis Date: 10/31/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ -5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
416 030107228-0001	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
417 030107228-0002	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
418 030107228-0003	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
419 030107228-0004	1340.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
420 030107228-0005	1320.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
421 030107228-0006	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
422 030107228-0007	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
423 030107228-0008	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
424 030107228-0009	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
425 030107228-0010	1280.00	0.0625	0	None Detected		0.0048	<16.00 <0.0048	
426 030107228-0011	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	

George William (20)


 Laboratory Manager
 or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NY, AP, or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NY/AP PLM/TEM #101048-9, NY State ELAP #11506

TEMAHERA-1

1

CITY_21MC100_002859194

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email:

EMSLAttn: Victor Escalona
Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117

Phone: 718-792-2832

Project: Building 1 80 North Moore Street NY NY

Customer ID: COMM56

Customer PO:

Received: 10/31/01 1:26 PM

EMSL Order: 030107228


EMSL Project ID:

Analysis Date: 10/31/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
427 030107228-0012	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
428 030107228-0013	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
429 030107228-0014	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
430 030107228-0015	1310.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
431 030107228-0016	1380.00	0.0625	0	None Detected		0.0045	<16.00 <0.0045	
432 030107228-0017	1380.00	0.0625	0	None Detected		0.0045	<16.00 <0.0045	
433 030107228-0018	1380.00	0.0625	0	None Detected		0.0045	<16.00 <0.0045	
434 030107228-0019	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
435 030107228-0020	1360.00	0.0625	0	None Detected		0.0045	<16.00 <0.0045	
436 030107228-0021	1570.00	0.0500	0	None Detected		0.0049	<20.00 <0.0049	
437 030107228-0022	1570.00	0.0500	0	None Detected		0.0049	<20.00 <0.0049	

George William (20)


 Laboratory Manager
 or other approved signatory

Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited to: NVLAP PLM-TEM #101048-9, NY State ELAP #11605

AHERA-1

CITY_21MC100_002859195

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

EMSL

Attn: Victor Escalona
Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117

Phone: 718-792-2832

Project: Building 1 80 North Moore Street NY NY

Customer ID: COMM56

Customer PO:

Received: 10/31/01 1:26 PM

EMSL Order: 030107228


EMSL Project ID:

Analysis Date: 10/31/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)	Notes
438 030107228-0023	1570.00	0.0500	0	None Detected		0.0049	<20.00 <0.0049	
439 030107228-0024	1550.00	0.0625	0	None Detected		0.0040	<16.00 <0.0040	
440 030107228-0025	1520.00	0.0625	0	None Detected		0.0041	<16.00 <0.0041	
441 030107228-0026	1450.00	0.0625	0	None Detected		0.0042	<16.00 <0.0042	
442 030107228-0027	1450.00	0.0625	0	None Detected		0.0042	<16.00 <0.0042	
443 030107228-0028	1450.00	0.0625	0	None Detected		0.0042	<16.00 <0.0042	
444 030107228-0029	1490.00	0.0625	0	None Detected		0.0041	<16.00 <0.0041	
445 030107228-0030	1460.00	0.0625	0	None Detected		0.0042	<16.00 <0.0042	
446 030107228-0031	1330.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
447 030107228-0032	1330.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
448 030107228-0033	1330.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	

George William (20)


Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/m³, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/m³. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101646-9, NY State ELAP #11506.

TEM AHERA-1

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

EMSLAttn: Victor Escalona
Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117

Phone: 718-792-2832

Project: Building 1 80 North Moore Street NY NY

Customer ID: COMM56

Customer PO:

Received: 10/31/01 1:26 PM

EMSL Order: 030107228


EMSL Project ID:

Analysis Date: 10/31/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ -5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²) (S/cc)	Notes
449 030107228-0034	1390.00	0.0625	1	None Detected		0.0044	<16.00 <0.0044	
450 030107228-0035	1370.00	0.0625	1	None Detected		0.0045	<16.00 <0.0045	
451 030107228-0036	1250.00	0.0625	3	None Detected		0.0049	<16.00 <0.0049	
452 030107228-0037	1250.00	0.0625	3	Chrysotile	0 1	0.0049	16 0.0049	
453 030107228-0038	1250.00	0.0625	1	None Detected		0.0049	<16.00 <0.0049	
454 030107228-0039	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
455 030107228-0040	1300.00	0.0625	3	Chrysotile	1 0	0.0047	16 0.0047	
456 030107228-0041	1320.00	0.0625	1	None Detected		0.0047	<16.00 <0.0047	
457 030107228-0042	1320.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
458 030107228-0043	1320.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
459 030107228-0044	1330.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	

George William (20)


 Laboratory Manager
 or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM711 M#101148-9 NY State ELAP #1150b

TEM AHERA 1

4

CITY_21MC100_002859197

EMSL**New York Lab**

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email:

Attn: Victor Escalona
Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117 Phone: 718-792-2832

Project: Building 1 80 North Moore Street NY NY

Customer ID: COMM56

Customer PO:

Received: 10/31/01 1:26 PM

EMSL Order: 030107228

EMSL Project ID:

Analysis Date: 10/31/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ -5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
							(S/mm ²)	(S/cc)	
460 030107228-0045	1330.00	0.0625	0	None Detected		0.0046	<16.00	<0.0046	
461 030107228-0046	1350.00	0.0625	0	None Detected		0.0046	<16.00	<0.0046	
462 030107228-0047	1350.00	0.0625	0	None Detected		0.0046	<16.00	<0.0046	
463 030107228-0048	1350.00	0.0625	0	None Detected		0.0046	<16.00	<0.0046	
464 030107228-0049	1350.00	0.0625	0	None Detected		0.0046	<16.00	<0.0046	
465 030107228-0050	1340.00	0.0625	0	None Detected		0.0046	<16.00	<0.0046	

George William (20)



Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for: NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEM AHERA-1

5

CITY_21MC100_002859198