

EMSL Analytical, Inc.

208 Stonehinge Lane

Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise

270 Swinton Avenue

Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ < 5μ	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
522	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
523	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
524	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
525	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
526	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
527	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045

Earl Tracey

Analyst

Approved
Signatory


Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by EPA, AHERA, or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

EMSL Analytical, Inc. 208 Stonehinge Lane, Carle Place, NY 11514
Tel: (516) 997-7251 Fax: (516) 997-7528

CITY_21MC100_002859270

EMSL Analytical, Inc.208 Stonehinge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
528	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
529	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
530	1330.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
531	1320.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
532	1420.00	None Detected		0	0.0635	0.0043	<15.75	<0.0043
533	1420.00	None Detected		0	0.0635	0.0043	<15.75	<0.0043

Earl Tracey

Analyst

Approved
Signatory


Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by monitoring personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NPLAP or any agency or the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory accreditation accuracy and precision) are available upon request.

Approved for NPLAP PLUMSBY #01246-00, EMILAP #1460, CALAP #224, LIT #1460

CITY_21MC100_002859271

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
534	1420.00	None Detected		0	0.0635	0.0043	<15.75	<0.0043
535	1430.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
536	1440.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
537	1500.00	None Detected		0	0.0635	0.0040	<15.75	<0.0040
538	1500.00	None Detected		0	0.0635	0.0040	<15.75	<0.0040
539	1500.00	None Detected		0	0.0635	0.0040	<15.75	<0.0040

Earl Tracey

Analyst

Approved
Signatory

Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NMLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analyst accuracy and precision) is available upon request.


3

File: NMLAP\BIN\BIN#101048-10 NY ELEM LAB# 02 FLAP2 BY: 07/08/01

CITY_21MC100_002859272

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
540	1550.00	None Detected		0	0.0508	0.0049	<19.69	<0.0049
541	1560.00	None Detected		0	0.0508	0.0049	<19.69	<0.0049
542	1620.00	None Detected		0	0.0508	0.0047	<19.69	<0.0047
543	1620.00	None Detected		0	0.0508	0.0047	<19.69	<0.0047
544	1620.00	None Detected		0	0.0508	0.0047	<19.69	<0.0047
545	1690.00	None Detected		0	0.0508	0.0045	<19.69	<0.0045

Earl Tracey

Analyst


 Approved
Signatory

Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NYS or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

EMSL Analytical, Inc. is a member of the NYS Laboratory Accreditation Board (NYS LAB AB) and is a member of the NYS Laboratory Accreditation Board (NYS LAB AB).

CITY_21MC100_002859273

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
546	1660.00	None Detected		0	0.0508	0.0046	<19.69	<0.0046
547	1550.00	None Detected		0	0.0508	0.0049	<19.69	<0.0049
548	1550.00	None Detected		0	0.0508	0.0049	<19.69	<0.0049
549	1550.00	None Detected		0	0.0508	0.0049	<19.69	<0.0049
550	1560.00	None Detected		0	0.0508	0.0049	<19.69	<0.0049
551	1550.00	None Detected		0	0.0508	0.0049	<19.69	<0.0049

Earl Tracey

Analyst


 Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

5

CITY_21MC100_002859274

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			≥ 0.5μ - < 5μ	≥ 5μ Non-Asbestos			(S/mm ²)	(S/cc)
552	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
553	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
554	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
555	1320.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
556	1310.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
557	1230.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049

Earl Tracey

Analyst


 Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used in claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analyst accuracy and precision) is available upon request.

EMSL Analytical, Inc. 208 Stonehenge Lane, Carle Place, NY 11514
 Phone: (516) 997-7251 Fax: (516) 997-7528
 E-mail: info@emsl-analytical.com Website: www.emsl-analytical.com

CITY_21MC100_002859275

EMSL Analytical, Inc.208 Stonching Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
558	1230.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
559	1230.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
560	1630.00	None Detected		0	0.0508	0.0046	<19.69	<0.0046
561	1250.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
562	1250.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
563	1250.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049

Earl Tracey

Analyst


 Approved
 Signatory


Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NPLA or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

7

CITY_21MC100_002859276

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - $< 5\mu$	$\geq 5\mu$ Non- Asbestos			(S/mm ³)	(S/cc)
564	1250.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
565	1250.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
566	1250.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
567	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
568	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
569	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047

Earl Tracey

Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependant on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

5

EMSL Analytical, Inc. is a subsidiary of EMSL Environmental Systems, Inc. (EESI) located at 208 Stonehenge Lane, Carle Place, NY 11514. EESI is a subsidiary of EESI Environmental Systems, Inc. (EESI) located at 208 Stonehenge Lane, Carle Place, NY 11514. EESI is a subsidiary of EESI Environmental Systems, Inc. (EESI) located at 208 Stonehenge Lane, Carle Place, NY 11514.

CITY_21MC100_002859277

EMSL Analytical, Inc.

208 Stonehenge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, November 03, 2001

Ref Number: LI0116678


Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG 1 80 N. MOORE ST NY, NY 19TH FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - $< 5\mu$	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
570	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
571	1290.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
572	0.00	None Detected		0	0.0635		<15.75	
573	0.00	None Detected		0	0.0635		<15.75	
574	0.00	None Detected		0	0.0635		<15.75	

Earl Tracey

Analyst


Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by MVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

CITY_21MC100_002859278