

022/023



AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

CLIENT: Warren & Panzer Engineers, P.C.
LABORATORY ID #: T02-09-080
ANALYT. METHODOLOGY: AHERA
FILTER TYPE: M.C.E.
AVERAGE G.O. AREA (mm^2): 0.013838

PROJECT: NYC DEP, 60 W. Main St.
DATE OF REPORT: 09/23/02
DATE OF ANALYSIS: 09/23/02
EFFECTIVE FILTER AREA (mm^2): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (l)	G.O.'s ANALYZED	AREA ANALYZED (mm^2)	ANALYT. SENSITIV. (struc./ cm^2)	TOTAL ASBESTOS AIR CONC. (struc./ cm^2)	TOTAL ASBESTOS FILTER CONC. (struc./ mm^2)	AIR CONC. FOR STRUCT. (0.558 μm)	AIR CONC. FOR STRUCT. (8.25 μm)	ASBEST. TYPE CHRVs.	AMPHIB. ASBEST. TYPE SPECIFY
ID01	T02-09-080-2470	IWA left side of WA	1800	4	0.0554	SAMPLE OVERLOADED WITH PARTICULATE MATERIAL. RENDERING IT UNACCEPTABLE FOR ANALYSIS						
ID02	T02-09-080-2471	By the decon	1800	4	0.0554	SAMPLE OVERLOADED WITH PARTICULATE MATERIAL. RENDERING IT UNACCEPTABLE FOR ANALYSIS						
ID03	T02-09-080-0272	By the stair-way	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA
ID04	T02-09-080-2473	IWA first right side of WA	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA
ID05	T02-09-080-2474	IWA second right side of WA	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA

E. Sioukri

ANALYST
E. Sioukri

Spino Dongaris

LABORATORY DIRECTOR
Spino Dongaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, FLAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

09/23/2002 09:31 FAX 7187844085

CITY_21MC100_002859972