

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 08-09-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers Street, NY

PROJECT NUMBER: M477-15217-29881

SAMPLED BY: Client

SAMPLE DATE: 08-08-02
DATE RECEIVED: 08-09-02
DATE ANALYZED: 08-09-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
LW-01	21023	Rm 711 Floor Center of Bathroom	<9.0	9.0
LW-02	21023	Rm 713 Floor Center of Bathroom	<9.0	9.0
LW-03	21023	Rm 705 Floor 3' North of South Wall Cabinet	<9.0	9.0
LW-04	21023	Rm 705 Table Top North Side Lab Table	<9.0	9.0
LW-05	21023	Rm 715 Floor	<9.0	9.0
LW-06	21023	Rm 715 Desk Top SE Desk	<9.0	9.0
LW-07	21023	Rm 717 Floor 3' of Main Entrance	<9.0	9.0
LW-08	21023	Rm 717 Table Top Teachers Table	<9.0	9.0
LW-09	21023	Rm 719 Floor 6' of Entrance	<9.0	9.0
LW-10	21023	Rm 719 Book Shelf East Side	<9.0	9.0
LW-11	21023	Rm C721 Floor West Side Center	<9.0	9.0
LW-12	21023	Rm 727 Floor 2' of West Unitvent	<9.0	9.0
LW-13	21023	Rm 727 Table Top West Sink Table	<9.0	9.0
LW-14	21023	Rm 727A Floor Center of Room	<9.0	9.0
LW-15	21023	Rm 727A Shelf North Side Shelf	<9.0	9.0

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

LW-16	21023	Rm 728 Floor Center of Room	<9.0	9.0
LW-17	21023	Rm 726 Floor	<9.0	9.0
LW-18	21023	Rm 726 Floor Table Top SW Side of Room	<9.0	9.0
LW-19	21023	Rm C728 Floor Service Elev. Lobby	<9.0	9.0
LW-20	21023	Rm 730 Floor Center of Bathroom	<9.0	9.0
FB-1	21023	Field Blank	<9.0 µg	9.0 µg
FB-2	21023	Field Blank	<9.0 µg	9.0 µg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft²,Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg

CERTIFICATION AND SIGNATURESANALYSIS PERFORMED BY: JKREPORT PREPARED BY: ATC

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: MSLABORATORY DIRECTOR: ML

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).