

ATC ASSOCIATES, INC.
 104 E 25th Street, 10th Floor
 New York, NY 10010
 Tel. 212-353-8280
 Fax 212-353-8306

REPORT DATE: 08-12-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
 345 Chambers Street, NY

PROJECT NUMBER: M477-15217-29881

SAMPLED BY: Client

SAMPLE DATE: 08-11-02
 DATE RECEIVED: 08-11-02
 DATE ANALYZED: 08-11-02

SAMPLE MEDIA: Dust Wipe Sample
 ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
LW-01	21059	Rm 601 Floor Centre of Room	<9.0	9.0
LW-02	21059	Rm 601 Table Top South Side Table	<9.0	9.0
LW-03	21059	Rm 601A Floor 3' of Entrance	<9.0	9.0
LW-04	21059	Rm 601A Top of File Cabinet	<9.0	9.0
LW-05	21059	Rm 601B Floor 10' of Entrance	<9.0	9.0
LW-06	21059	Rm 601B Top of File Table	<9.0	9.0
LW-07	21059	Rm C621 Floor Right of Entrance	<9.0	9.0
LW-08	21059	Rm C623 Floor Center of Room	<9.0	9.0
LW-09	21059	6th Floor Corridor O/S Rm 615 Main Ent. Floor	<9.0	9.0
LW-10	21059	6th Floor Corridor O/S Rm 601 Floor	<9.0	9.0
LW-11	21059	Locker #6-53 Floor of Locker	<9.0	9.0
LW-12	21059	Rm C632 (Slop Sink) Floor	<9.0	9.0
FBL-1	21059	Field Blank	<9.0 μg	9.0 μg
FBL-2	21059	Field Blank	<9.0 μg	9.0 μg

ATC ASSOCIATES, INC.
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$.

Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.

NOTE 3:

Blank units are in μg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

RD

REPORT PREPARED BY: _____

[Signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

[Signature]

LABORATORY DIRECTOR: _____

[Signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).