

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 07-29-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers Street, NY

PROJECT NUMBER: M477-15217/29881

SAMPLED BY: Client

SAMPLE DATE: 07-27-02
DATE RECEIVED: 07-28-02
DATE ANALYZED: 07-28-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft²)	DETECTION LIMIT (µg/ft²)
LW-01	20715	Rm 327 South Side Left Unitvent Rear	<9.0	9.0
LW-02	20715	Rm 327 South Side Right Unitvent Rear	<9.0	9.0
LW-03	20715	Rm 335 South Side Left Unitvent Rear	<9.0	9.0
LW-04	20715	Rm 335 South Side Right Unitvent Rear	<9.0	9.0
LW-05	20715	Rm 337 South Side Left Unitvent Rear	<9.0	9.0
LW-06	20715	Rm 337 South Side Right Unitvent Rear	<9.0	9.0
LW-07	20715	Rm 339 South Side Left Unitvent Rear	<9.0	9.0
LW-08	20715	Rm 339 South Side Right Unitvent Rear	<9.0	9.0
FBL-1	20715	Field Blank	<9.0 µg	9.0 µg
FBL-2	20715	Field Blank	<9.0 µg	9.0 µg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg