

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 07-29-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
3rd, 8th and 9th Floors

PROJECT NUMBER: M477-15217/29881

SAMPLED BY: Client

SAMPLE DATE: 07-27-02
DATE RECEIVED: 07-27-02
DATE ANALYZED: 07-27-02

SAMPLE MEDIA: Air Samples
ANALYSIS REQUIRED: Method NIOSH 7082

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{m}^3$)	DETECTION LIMIT ($\mu\text{g}/\text{m}^3$)
01	20704	Rm 802A at Entrance	<3.1	3.1
02	20704	Rm 807 at Entrance	<3.1	3.1
03	20704	Rm 817 at Entrance	<3.1	3.1
04	20704	Rm 911 at Entrance	<3.1	3.1
05	20704	Rm 329 at Entrance	<3.1	3.1
06	20704	Rm 802A at Entrance	<5.0	5.0
07	20704	Rm 817 at Entrance	<5.0	5.0
08	20704	Rm 911 at Entrance	<4.2	4.2
09	20704	Rm 329 at Entrance	<4.7	4.7
FB-10	20704	Field Blank	<1.5 μg	1.5 μg
FB-11	20704	Field Blank	<1.5 μg	1.5 μg

NOTE 1:

THE REPORTING LIMIT (RL) IS 3.0 μg

NOTE 2:

At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu\text{g}/\text{m}^3$ and a permissible exposure level (PEL) of 50 $\mu\text{g}/\text{m}^3$ for personal samples.

NOTE 3:

Blank units are in μg