

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr Ben Sallemi
 ATC Associates Inc
 104 East 25th Street
 New York NY 10010

Received: 2/24/02 6 00 00 AM
ATC Group #: 6804
Analysis Date: 2/24/02

Fax: (212) 353-3599 **Phone:** (212) 353-8280

Project: 99 Church
 99 Church Street, New York NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
1 6804 -1	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
2 6804 -2	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
3 6804 -3	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
4 6804 -4	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
5 6804 -5	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
6 6804 -6	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
7 6804 -7	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
8 6804 -8	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044

ROMAN PEYSAKHOV

Analyzed by

MICHAEL A. GORYCKI, Ph D

Approved by

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_002842240

Attn: Mr Ben Sallemi
 ATC Associates Inc
 104 East 25th Street
 New York NY 10010

Received: 2/24/02 6:00:00 AM
ATC Group #: 6804
Analysis Date: 2/24/02

Fax: (212) 353-3599 **Phone:** (212) 353-8280

Project: 99 Church
 99 Church Street, New York NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
9 6804 -9	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
10 6804 -10	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	

ROMAN PEYSAKHOV

Analyzed by



MICHAEL A. GORYCKI, Ph.D.

Approved by



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879