

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn:

Taylor Environmental Group

Received: 8/29/02 2:30:00 PM

ATC Group #: 8783

Analysis Date: 8/29/02

Fax: (516) 358-1780

Phone:

Project: NYC SCA Project #: M477-15217-29881

Stuyvesant H. S., Chambers Street, NY, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Analytical		Sensitivity (S/cc)	Asbestos Concentration		Notes
					# Structures 0.5u-5 µ	µm		(S/mmt ²)	(S/cc)	
IT-1 8783 -1	1300.50	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
IT-2 8783 -2	1258.00	0.0674	0	None Detected	0	0	0.0045	<14.83	<0.0045	
IT-3 8783 -3	1266.50	0.0674	0	None Detected	0	0	0.0045	<14.83	<0.0045	
IT-4 8783 -4	1303.75	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
IT-5 8783 -5	1332.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043	
IT-6 8783 -6	1341.25	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043	
IT-7 8783 -7	1232.50	0.0674	0	None Detected	0	0	0.0046	<14.83	<0.0046	

MARK PEYSAKHOV

Analyzed by

MICHAEL A. GORYCKI, Ph.D.

Approved by

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 2

CITY_21MC100_002848864

Attn:

Taylor Environmental Group

Received: 8/29/02

2:30:00 PM

ATC Group #: 8783

Analysis Date: 8/29/02

Fax: (516) 358-1780

Phone:

Project: NYC SCA Project #: M477-15217-29881

Stuyvesant H. S., Chambers Street, NY, NY.

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
IT-8 8783 -8	1268.75	0.0674	0	None Detected	0	0	0.0045	<14.83	<0.0045
IT-9 8783 -9	1305.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
IT-10 8783 -10	1268.75	0.0674	0	None Detected	0	0	0.0045	<14.83	<0.0045

MARK PEYSAKHOV

Analyzed by



MICHAEL A. GORYCKI, Ph.D

Approved by

Disclaimer: The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879