

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel 212-353-8280
Fax 212-353-8306

REPORT DATE: 08-05-02
CLIENT: Taylor Environmental Group, Inc.
PROJECT NAME: SCA/Stuyvesant HS
345 Chambers Street, NY
PROJECT NUMBER: M477-15217/29881
SAMPLED BY: Client
SAMPLE DATE: 08-02-02
DATE RECEIVED: 08-02-02
DATE ANALYZED: 08-02-02
SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
DW-01	20871	Rm 501A Ceiling Unitvent Air Damper	<9.0	9.0
DW-02	20871	Rm 231 Left Unitvent Back Wall	<9.0	9.0
DW-03	20871	Rm 231 Right Unitvent Back Wall	<9.0	9.0
DW-04	20871	Field Blank	<9.0 μg	9.0 μg
DW-05	20871	Field Blank	<9.0 μg	9.0 μg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$, Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.

NOTE 3:

Blank units are in μg CERTIFICATION AND SIGNATURESANALYSIS PERFORMED BY: BDREPORT PREPARED BY: [Signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: [Signature]LABORATORY DIRECTOR: [Signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).