

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Robert Lewin
ATC Associates Inc.

104 East 25th Street

New York

NY 10010

Fax: (212) 353-3599

Phone: (212) 353-8280

Received: 1/3/02

8:00:00 AM

ATC Group #: 6255

Analysis Date: 1/3/02

Project: Tribeca Towers

105 Duane Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
1 6255 -1	1547.00	0.0562	0	None Detected	0	0	0.0044	<17.79	<0.0044	
3 6255 -2	1360.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042	

MARK PEYSAKHOV

Analyzed by:

A handwritten signature in black ink, appearing to read 'Mark PeySAkhov'.

MICHAEL A. GORYCKI, Ph.D.

Approved by:

A handwritten signature in black ink, appearing to read 'Michael A. Gorycki'.

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency or the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_002849468