



CLIENT [Redacted]
PROJECT NO. (ATHENICA FILE#) 01-05-05

SITE 46 Trinity place (N.Y.C.)
DATE 10/15/01

PURPOSE OF MONITORING AREA SAMPLING

TECHNICIAN Mohammed & Victor

CASSETTE SIZE 25 mm LOT# [Redacted]

ROTOMETER# 5010 BATCH# T01-10-010

TYPE-OF-RESPIRATOR [Redacted]

PROJECT MANAGER [Redacted]

AREAS OF ABATEMENT 2nd, 3rd, 4th & 5th floor

TYPE-OF-REMOVAL N/A

PCM ☐ TEM ☒
CHECK ONLY ONE BOX

Background ☐ Pre-Abatement ☐ Durrings ☐ Finals ☐ Others (Explain) Ambience
(CHECK ONLY ONE BOX)

Asb. 5745 Asb. 5745

SAMPLE ID#	LOCATION	TYPE *	PUMP	TIME		TOTAL MIN.	FLOW			VOLUME	FIBERS/ FIELD	FIBERS/ C.C.
				IN	OUT		BEFORE	AFTER	AVERAGE			
01	(2nd floor) center	OTH		0950	1255	185	10	10	10	1850	<19.94	<0.0041
02	west side			0952	1256	184	10	10	10	1840	<19.94	<0.0042
03	East side			0954	1257	183	10	10	10	1830	19.94	0.0042
04	(2nd floor) East side	OTH		0958	1300	182	10	10	10	1820	<19.94	<0.0042
05	center			1000	1301	181	10	10	10	1810	<19.94	<0.0042
06	west side			1001	1302	181	10	10	10	1810	<19.94	<0.0042
07	(4th floor) center	OTH		1005	1305	180	10	10	10	1800	<19.94	<0.0042
08	East side			1006	1306	180	10	10	10	1800	<19.94	<0.0042
09	west side			1008	1308	180	10	10	10	1800	<19.94	<0.0042
10	(5th floor) East side	OTH		1017	1318	183	10	10	10	1830	<19.94	<0.0042
11	center			1014	1317	183	10	10	10	1830	<19.94	<0.0042
12	west side			1015	1318	183	10	10	10	1830	<19.94	<0.0042

BGA - Background
PRE - Preabatement

IWA - Inside Work Area
OB - Outside Building

ICR - Inside Clean Room
NGAE - Negative Air Exhaust

OWA - Outside work area
OTH - Other

OFNL - Outside Finals
IFNL - Inside Finals

CHAIN OF CUSTODY RECORD

RELINQUISHED BY:	<u>[Signature]</u>	DATE:	<u>10-15-01</u>	TIME:	<u>0315 PM</u>
RECEIVED BY:	<u>[Signature]</u>	DATE:	<u>10/15/01</u>	TIME:	
ANALYST:	<u>[Signature]</u>	DATE:	<u>10/16/01</u>	TIME:	

LABORATORY ACCREDITATION:
NVLAP# 101958 ELAP# 10955 METHOD: NIOSH 7400

WHITE-FILE/LAB YELLOW-CLIENT/REPORT PINK-FIELD