

**HILLMANN ENVIRONMENTAL GROUP, L.L.C.**

ENVIRONMENTAL CONSULTING & LAB SERVICES

1600 ROUTE 22 EAST

P.O. BOX 1597

UNION, NEW JERSEY 07083-1597

(908) 688-7800

FAX (908) 688-7800

www.hillmanngroup.com

Date of Sampling: December 3, 2001**Date of Sample Receipt:** December 5, 2001**To:** 102-104 Greenwich St Manhattan
255 47th Street
Brooklyn, NY 11220

Attn: Ms. Essa Betah

Location: 104 Greenwich St/New York/NY
HECO# Y1-3619**Procedure:** Preparation**Field Technician:** CUASCUT, DETRICK**Date of Analysis:** December 5, 2001**Date of Issue:** December 7, 2001**AIR SAMPLE CERTIFICATE OF ANALYSIS**

Method: Phase Contrast Microscopy: NIOSH 7400; Issue #2, 1994/ELAP ID 10926

<u>LAB ID#</u>	<u>LOCATION/SAMPLE ID</u>	<u>VOLUME(LITERS)</u>	<u>FIBERS/CC</u>
K62572	1st Fl/Within Back Stairwell	1345	<0.002
K62573	2nd Fl/Within Back Stairwell	1355	<0.002
K62574	3rd Fl/Within Back Stairwell	1365	<0.002
K62575	1st Fl/Front Door/Stair Entry	1375	<0.002
K62576	1st Fl/Within Center of Bar	1380	<0.002

Analyst Signature: _____

ELLIS, BENJAMIN, J. , ASSISTANT MANAGER

(<) Indicates results are below the limit of detection (LOD). LOD is based on 5.5 fibers/100 fields.

Page 1 of 2



CITY_21MC100_002849669



HILLMANN ENVIRONMENTAL GROUP, L.L.C.
ENVIRONMENTAL CONSULTING & LAB SERVICES

Continuation

To: 102-104 Greenwich St Manhattan

Location: 104 Greenwich St/New York/NY
HECO# Y1-3619

Procedure: Preparation

AIR SAMPLE CERTIFICATE OF ANALYSIS

Method: Phase Contrast Microscopy: NIOSH 7400; Issue #2, 1994/ELAP ID 10926

<u>LAB ID#</u>	<u>LOCATION/SAMPLE ID</u>	<u>VOLUME(LITERS)</u>	<u>FIBERS/CC</u>
		<u>FIBERS/100 FIELDS</u>	
K62577	Field Blank	ND	
K62578	Field Blank	ND	

Analyst Signature: _____

ELLIS, BENJAMIN, J. , ASSISTANT MANAGER

(<) Indicates results are below the limit of detection (LOD). LOD is based on 5.5 fibers/100 fields.

Page 2 of 2



CITY_21MC100_002849670