

**HILLMANN ENVIRONMENTAL GROUP, L.L.C.**
ENVIRONMENTAL CONSULTING & LAB SERVICES

1600 ROUTE 22 EAST

P.O. BOX 1597

UNION, NEW JERSEY 07083-1597

(908) 688-7800

FAX (908) 688-7800

www.hillmanngroup.com

Date of Sampling: December 5, 2001**Date of Sample Receipt:** December 7, 2001**To:** 102-104 Greenwich St Manhattan
255 47th Street
Brooklyn, NY 11220

Attn: Ms. Essa Betah

Location: 102-104 Greenwich St/New York/NY
5 Story Building
HECO# Y1-3619**Procedure:** During Clean Up**Field Technician:** CUASCUT, DETRICK F**Date of Analysis:** December 7, 2001**Date of Issue:** December 13, 2001**AIR SAMPLE CERTIFICATE OF ANALYSIS**

Method: Phase Contrast Microscopy: NIOSH 7400; Issue #2, 1994/ELAP ID 10926

<u>LAB ID#</u>	<u>LOCATION/SAMPLE ID</u>	<u>VOLUME(LITERS)</u>	<u>FIBERS/CC</u>
K63157	3rd Fl/Within Decon	2450	0.002
K63158	Within 3rd & 2nd Fl Hallway Back Stairwell	2445	<0.002
K63159	Within 2nd & 1st Fl Hallway Back Stairwell	2445	<0.002
K63160	1st Fl/Within 10' of Hallway Front Door	2440	<0.002
K63161	Within Front Stairwell to 2nd Fl Sitting Area	2430	<0.002

Analyst Signature: _____

ELLIS, BENJAMIN, J. , ASSISTANT MANAGER

(<) Indicates results are below the limit of detection (LOD). LOD is based on 5.5 fibers/100 fields.

Page 1 of 2



CITY_21MC100_002849673



HILLMANN ENVIRONMENTAL GROUP, L.L.C.
ENVIRONMENTAL CONSULTING & LAB SERVICES

Continuation

To: 102-104 Greenwich St Manhattan

Location: 102-104 Greenwich St/New York/NY
5 Story Building
HECO# Y1-3619

Procedure: During Clean Up

AIR SAMPLE CERTIFICATE OF ANALYSIS

Method: Phase Contrast Microscopy: NIOSH 7400; Issue #2, 1994/ELAP ID 10926

<u>LAB ID#</u>	<u>LOCATION/SAMPLE ID</u>	<u>VOLUME(LITERS)</u>	<u>FIBERS/CC</u>
		<u>FIBERS/100 FIELDS</u>	
K63162	Field Blank	ND	
K63163	Field Blank	ND	

Analyst Signature: _____

ELLIS, BENJAMIN, J. , ASSISTANT MANAGER

(<) Indicates results are below the limit of detection (LOD). LOD is based on 5.5 fibers/100 fields.

Page 2 of 2



CITY_21MC100_002849674