

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 23, 2001


Ref Number: LI0116152

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**Project: BUILDING # 9 310 GRENNWICH STREET NYC, NY/30TH FLOOR FILE NO. 01231.**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
50	1240.00	Chrysotile	1	0	0.0635	0.0049	15.75	0.0049
54	1250.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
55	1260.00	None Detected		0	0.0635	0.0048	<15.75	<0.0048
56	1270.00	None Detected		0	0.0635	0.0048	<15.75	<0.0048
57	1250.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
58	1260.00	None Detected		0	0.0635	0.0048	<15.75	<0.0048

Daniel Clarke

Analyst


 Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_002843206

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 23, 2001


Ref Number: LI0116152

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)****Project: BUILDING # 9 310 GREENWICH STREET NYC, NY/30TH FLOOR FILE NO. 01231.**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
59	1250.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
60	1250.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
61	1250.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
62	1310.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
63	0.00	Not Submitted		0	0.0000			
64	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045

Daniel Clarke

Analyst


 Approved
 Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

2

Accredited for NVLAP: PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_002843207

EMSL Analytical, Inc.208 Stonehinge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 23, 2001

Ref Number: LI0116152

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)****Project: BUILDING # 9 310 GRENNWICH STREET NYC, NY/30TH FLOOR FILE NO. 01231.**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
65	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
66	1360.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
67	1340.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
68	1340.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
69	1400.00	None Detected		0	0.0635	0.0043	<15.75	<0.0043
70	1400.00	None Detected		0	0.0635	0.0043	<15.75	<0.0043


Daniel Clarke

Analyst


 Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

3


 Accredited for NVLAP PLM/TEM #1C1048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_002843208

EMSL Analytical, Inc.

208 Stonehenge Lane

Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise

270 Swinton Avenue

Bronx, NY 10465

Tuesday, October 23, 2001

Ref Number: LI0116152

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: BUILDING # 9 310 GRENNWICH STREET NYC, NY/30TH FLOOR FILE NO. 01231.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
71	1400.00	None Detected		0	0.0635	0.0043	<15.75	<0.0043
72	1410.00	None Detected		0	0.0635	0.0043	<15.75	<0.0043
73	1400.00	None Detected		0	0.0635	0.0043	<15.75	<0.0043
74	1230.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
75	1230.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
76	1240.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049

Daniel Clarke

Analyst


 Approved
 Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mini². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

4

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_002843209

EMSL Analytical, Inc.

208 Stonehenge Lane

Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise

270 Swinton Avenue

Bronx, NY 10465

Tuesday, October 23, 2001

Ref Number: LI0116152


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: BUILDING # 9 310 GREENWICH STREET NYC, NY/30TH FLOOR FILE NO. 01231.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ < 5μ	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
77	1220.00	Chrysotile	1	0	0.0635	0.0050	15.75	0.0050
78	2400.00	None Detected		0	0.0635	0.0025	<15.75	<0.0025
79	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
80	1310.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
81	1320.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
82	1200.00	None Detected		0	0.0635	0.0051	<15.75	<0.0051

Daniel Clarke

Analyst


 Approved
 Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

5

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2539, C1 PH-0249

CITY_21MC100_002843210

EMSL Analytical, Inc.208 Stonehinge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 23, 2001

Ref Number: LI0116152

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: BUILDING # 9 310 GRENNWICH STREET NYC, NY/30TH FLOOR FILE NO. 01231.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu -$ $< 5\mu$	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
83	1200.00	None Detected		0	0.0635	0.0051	<15.75	<0.0051
84	1540.00	None Detected		0	0.0635	0.0039	<15.75	<0.0039
85	1540.00	None Detected		0	0.0635	0.0039	<15.75	<0.0039
86	1540.00	None Detected		0	0.0635	0.0039	<15.75	<0.0039
87	1250.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
88	0.00	Not Submitted		0	0.0000			

Daniel Clarke

Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

6

Received for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_002843211

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 23, 2001

Ref Number: LI0116152

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)****Project: BUILDING # 9 310 GRENWICH STREET NYC, NY/30TH FLOOR FILE NO. 01231.**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
89	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
90	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
91	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
92	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
93	1530.00	None Detected		0	0.0635	0.0040	<15.75	<0.0040
94	1610.00	None Detected		0	0.0635	0.0038	<15.75	<0.0038

Daniel Clarke

Analyst


 Approved
 Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

7

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_002843212

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 23, 2001


Ref Number: LI0116152

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)****Project: BUILDING # 9 310 GRENNWICH STREET NYC, NY/30TH FLOOR FILE NO. 01231.**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
95	1600.00	None Detected		0	0.0635	0.0038	<15.75	<0.0038
96	1590.00	None Detected		0	0.0635	0.0038	<15.75	<0.0038
97	1550.00	None Detected		0	0.0635	0.0039	<15.75	<0.0039
98	0.00	Not Submitted		0	0.0000			
99	1470.00	None Detected		0	0.0635	0.0041	<15.75	<0.0041
100	1470.00	None Detected		0	0.0635	0.0041	<15.75	<0.0041

Daniel Clarke

Analyst


 Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

8

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_002843213

EMSL Analytical, Inc.208 Stonehinge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 23, 2001


Ref Number: LI0116152

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**Project: BUILDING # 9 310 GRENNWICH STREET NYC, NY/30TH FLOOR FILE NO. 01231.**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
101	1470.00	None Detected		0	0.0635	0.0041	<15.75	<0.0041
102	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
103	1950.00	None Detected		0	0.0635	0.0031	<15.75	<0.0031
104	0.00	None Detected		0	0.0635		<15.75	
105	0.00	None Detected		0	0.0635		<15.75	
106	0.00	None Detected		0	0.0635		<15.75	

Daniel Clarke

Analyst


 Approved
 Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

9

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_002843214