


EMSL Analytical, Inc.208 Stonelinge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, October 20, 2001

Ref Number: LI0116102

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: 310 GREENWICH ST. NY/NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES			Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			≥ 0.5μ - < 5μ	≥ 5μ	Non- Asbestos			(S/mm ²)	(S/cc)
1	1260.00	Chrysotile	1	0	0	0.0635	0.0048	15.75	0.0048
2	1260.00	None Detected			0	0.0635	0.0048	<15.75	<0.0048
3	1270.00	None Detected			1	0.0635	0.0048	<15.75	<0.0048
4	1270.00	None Detected			0	0.0635	0.0048	<15.75	<0.0048
5	1480.00	None Detected			0	0.0635	0.0041	<15.75	<0.0041
6	1290.00	None Detected			1	0.0635	0.0047	<15.75	<0.0047

Michelle McGowan

Analyst

Approved
Signatory


Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0240

CITY_21MC100_002843279

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, October 20, 2001

Ref Number: LI0116102

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: 310 GREENWICH ST. NY/NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ < 5μ	Non- Asbestos $\geq 5\mu$			(S/mm ²)	(S/cc)
7	1290.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
8	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
9	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
10	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
11	1320.00	None Detected		1	0.0635	0.0046	<15.75	<0.0046
12	1330.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046

Michelle McGowan

Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

2

EMSL Analytical, Inc. is a member of the NVLAP PCL/TEM #101048-10, NY ELAP 11405, CA ELAP 2339, CT PH-0249.

CITY_21MC100_002843280

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, October 20, 2001

Ref Number: LI0116102


Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: 310 GREENWICH ST. NY/NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES			Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			≥ 0.5μ - < 5μ	≥ 5μ	Non-Asbestos			(S/mm ³)	(S/cc)
13	1320.00	None Detected			0	0.0635	0.0046	<15.75	<0.0046
14	1320.00	Chrysotile	0	1	0	0.0635	0.0046	15.75	0.0046
15	1310.00	None Detected			0	0.0635	0.0046	<15.75	<0.0046
16	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.0045
17	1360.00	None Detected			1	0.0635	0.0045	<15.75	<0.0045
18	1360.00	None Detected			0	0.0635	0.0045	<15.75	<0.0045

Michelle McGowan

Analyst


 Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.


3

EMSL is a participant in the NVLAP program for TEM #101046-10, NY ELAP 11449, CA ELAP 1339, CI 191-0945

CITY_21MC100_002843281

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, October 20, 2001

Ref Number: LI0116102

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: 310 GREENWICH ST. NY/NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES			Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$	Non- Asbestos			(S/mm ²)	(S/cc)
19	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.0045
20	1330.00	Chrysotile	0	1	0	0.0635	0.0046	15.75	0.0046
21	1260.00	None Detected			1	0.0635	0.0048	<15.75	<0.0048
22	1280.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
23	1280.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
24	1260.00	None Detected			0	0.0635	0.0048	<15.75	<0.0048

Brian Riedener

Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

EMSL is a member of the NY State Office of Environmental Conservation (OEC) and is licensed for NY: AP PLM/TEM #101068, 10, NY ELAP 11450, CA ELAP 2249, CT PLM/TEM

CITY_21MC100_002843282

NYC-WTC_000210344

EMSL Analytical, Inc.208, Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, October 20, 2001

Ref Number: LI0116102

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: 310 GREENWICH ST. NY/NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ $< 5\mu$	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
25	1200.00	None Detected		0	0.0635	0.0051	<15.75	<0.0051
26	1600.00	None Detected		0	0.0635	0.0038	<15.75	<0.0038
27	1600.00	None Detected		0	0.0635	0.0038	<15.75	<0.0038
28	1600.00	None Detected		0	0.0635	0.0038	<15.75	<0.0038
29	1600.00	None Detected		0	0.0635	0.0038	<15.75	<0.0038
30	1600.00	None Detected		0	0.0635	0.0038	<15.75	<0.0038

Brian Riedener

Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.


Edited for NVLAP PLM/TEM #101045-10, NY ELAP 11465, CA ELAP 2360, CT P110249

CITY_21MC100_002843283

NYC-WTC_000210345

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, October 20, 2001

Ref Number: LI0116102

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: 310 GREENWICH ST. NY/NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES			Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$	Non- Asbestos			(S/mm ²)	(S/cc)
31	1420.00	Chrysotile	1	0	0	0.0635	0.0043	15.75	0.0043
32	1420.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
33	1430.00	None Detected			0	0.0635	0.0042	<15.75	<0.0042
34	1450.00	None Detected			0	0.0635	0.0042	<15.75	<0.0042
35	1450.00	None Detected			1	0.0635	0.0042	<15.75	<0.0042
36	1390.00	None Detected			0	0.0635	0.0044	<15.75	<0.0044

Brian Riedener

Analyst


 Approved
Signatory

Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analyst accuracy and precision) is available upon request.

6

Accredited for NVLAP PLM/TEM #101049-10 NY ELAP 11465, CA ELAP 2938, CT P#0249

CITY_21MC100_002843284

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, October 20, 2001

Ref Number: LI0116102

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: 310 GREENWICH ST. NY/NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES			Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			≥ 0.5μ - < 5μ	≥ 5μ	Non- Asbestos			(S/mm ²)	(S/cc)
37	1390.00	None Detected			0	0.0635	0.0044	<15.75	<0.0044
38	1400.00	Chrysotile	5	0	0	0.0635	0.0043	78.74	0.0217
39	1400.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
40	1380.00	None Detected			0	0.0635	0.0044	<15.75	<0.0044
41	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.0045
42	1350.00	None Detected			0	0.0635	0.0045	<15.75	<0.0045

Brian Riedener

Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

7

Registered for NVLAP PLM/TEM #101049-10, NY ELAP 11459, CA ELAP 2639, CT PH0019

EMSL Analytical, Inc.

208 Stonehenge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, October 20, 2001

Ref Number: LI0116102

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: 310 GREENWICH ST. NY/NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ $< 5\mu$	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
43	1340.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
44	1340.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
45	1340.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
46	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
47	1290.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
48	1280.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047

Brian Riedener

Analyst

Approved
Signatory

Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

8

Lab used for NVLAP PLM/TEM #101048-10 NY LIA #11400, CA EIA# 2339, CTP#0249

EMSL Analytical, Inc.208 Stonehinge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise

270 Swinton Avenue

Bronx, NY 10465

Saturday, October 20, 2001

Ref Number: LI0116102

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: 310 GREENWICH ST. NY/NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
49	1280.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047

Brian Riedener

Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limit, and laboratory and analysts' accuracy and precision), is available upon request.

9

Accredited for NVLAP PLM/TEM #101049-10, NY ELAP 11459, CA ELAP 2630, IL ELAP 0249

CITY_21MC100_002843287