


New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:



Attn: Victor Escalona
Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117

Phone: 718-792-2832

Project: 01231 / TOWN HOUSE / 51 HARRISON / INSIDE APTS

Customer ID: COMM56

Customer PO:

Received: 11/06/01 12:50 PM

EMSL Order: 030107554

EMSL Project ID:

Analysis Date: 11/6/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
634 030107554-0012	1210.00	0.0750	0	None Detected		0.0042	<13.33 <0.0042	
635 030107554-0013	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	
636 030107554-0014	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	
637 030107554-0015	1300.00	0.0625	0	Chrysotile	1 0	0.0047	16 0.0047	
638 030107554-0016	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
639 030107554-0017	1230.00	0.0750	0	None Detected		0.0042	<13.33 <0.0042	
640 030107554-0018	1230.00	0.0750	0	None Detected		0.0042	<13.33 <0.0042	

George William (18)

Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-S, NY State ELAP #11505

TC MAHERA-1

2

CITY_21MC100_002843362