

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:



Attn: Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117

Phone: 718-792-2832

Project: Town House 51 Harrison Street, New York NY- Inside
Apts.

Customer ID: COMM56

Customer PO:

Received: 11/07/01 11:45 AM

EMSL Order: 030107604

EMSL Project ID:

Analysis Date: 11/7/2001

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/nm ²) (S/cc)	Notes
544 030107604-0001	1250.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
545 030107604-0002	1250.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
546 030107604-0003	1250.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
547 030107604-0004	1250.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
548 030107604-0005	1200.00	0.0750	1	None Detected		0.0043	<13.33 <0.0043	
549 030107604-0006	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	
550 030107604-0007	1200.00	0.0750	1	None Detected		0.0043	<13.33 <0.0043	
551 030107604-0008	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	
552 030107604-0009	1250.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
553 030107604-0010	1250.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
554 030107604-0011	1260.00	0.0625	0	Chrysotile	1 0	0.0049	16 0.0049	

Jose Arriaga (12)

Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101049-9, NY State ELAP #11506

TEMAHERA-1

1

CITY_21MC100_002843363

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email:



Attn: Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117

Phone: 718-792-2832

Project: Town House 51 Harrison Street, New York NY- Inside
Apts.

Customer ID: COMM56

Customer PO:

Received: 11/07/01 11:45 AM

EMSL Order: 030107604


EMSL Project ID:

Analysis Date: 11/7/2001

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5μ - 5μ ≥ 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
555 030107604-0012	1280.00	0.0625	0	None Detected		0.0048	<16.00 <0.0048	

Jose Arriaga (12)


 Laboratory Manager
 or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for: NVLAP PLM/TEM #1016-46-9, NY State ELAP #11506

TEM/AHERA-1

CITY_21MC100_002843364