

NOV-21-01 WED 02:50 PM AMBIENT GROUP INC

FAX NO. 212 768 1540

P. 03/08

Ambient Group, Inc.
10 Morris Avenue,
Glen Cove 11542
(516) 609-0009

ELAP 10865

AIRBORNE ASBESTOS STRUCTURES RESULTS
(TRANSMISSION ELECTRON MICROSCOPY - TEM)

CLIENT: CUSHMAN & WAKEFIELD, INC.

LOCATION: 1 NORTH END AVENUE

PROJECT ID: 211338

DATE COLLECTED: 11/15/01

SAMPLE NUMBER	SAMPLE LOCATION	ASBESTOS STRUCTURES cm ³
4501-01 Field 4501	11:25 AM 10 th Floor/Adjacent to Room 1016 LT ANYL SENS	<0.0044
4501-02 Field 4501	11:40 AM 7 th Floor/Adjacent to Stair "C" LT ANYL SENS	<0.0045
4501-03 Field 4501	12:36 PM 3 rd Floor/Adjacent to stair "D" LT ANYL SENS	<0.0046
4501-04 Field 4501	12:07 PM 2 nd Floor/Adjacent to Trading Places Concierge LT ANYL SENS	<0.0045

LT ANYL SENS=LESS THAN ANALYTICAL SENSITIVITY

11/21/01 WED 14:53 [TX/RX NO 85671]

CITY_21MC100_002860979