NYC 9/11 Public Portal Document

AIRTEK ENVIRONMENTAL CORP	Date: 11/29/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 47 Code: FV

--Types of Project--

Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET

State: Zip:

Date Analyzed: 11/30/01

Sample	FV -1129-01	FV -1129-02	FV -1129-03	FV -1129-04	FV -1129-05
Location	ADJ,CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 15FT. EAST FROM 50 MURRAY ST.ENT	OWA,1ST FL. 20FT.WEST 50 MURRAY ST. ENTRANCE	IWA,1ST FL. WITHIN 10FT. FROM MAIN STAIRCASE	IWA,1ST FL. EAST ELEVATOR BANK
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -	- -	- -	- -	- -
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	11/29/01	11/29/01	11/29/01	11/29/01	11/29/01
Time On	07:20A	07:22A	07:23A	07:26A	07:27A
Time Off	10:00A	10:02A	10:03A	6A	10:07A
Tot Time	160 min	160		in	160 min
Tot Vol	1120 ltr	112(		ltr	1120 ltr
AV Cnt Fibr Per Fld	.03	.01			.01
Fibr Cnt Fibr Per CC	< 0.0024	< 0.0		24	< 0.0024
Comments					

11-29-01 PCM

ALL

22 (-)

ANALYSIS: NIOSH 7400 METHOD, A R... - NIKON LABOPHOT - PCM

Authorized Signature