


AIRTEK ENVIRONMENTAL CORP	Date: 12/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 171 Code: JG
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	JG -1221-01	JG -1221-02	JG -1221-03	JG -1221-04	JG -1221-05
Location	IWA,ADJ. TO TRANSFORMER RM ON 16TH FL.120 CHURCH	IWA,ADJ. TO TRANSFORMER RM ON 16TH FL.120 CHURCH	IWA,RIGHTSIDE OF TRANSFORMER RM ON 18TH FL	IWA,IN FRONT OF TRANSFORMER ON 18TH FL.	IWA,14TH FL. ADJ. TO TRANSFORMER RM 120 CHURCH
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				- -
Avg Flow	15.0	15.0	15.0	15.0	15.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	07:45P	07:46P	08:35P	08:35P	08:40P
Time Off	09:45P	09:46P	10:35P	10:35P	10:40P
Tot Time	120 min	120 min	120 min	120 min	120 min
Tot Vol	1800 ltr	1800 ltr	1800 ltr	1800 ltr	1800 ltr
AV Cnt Fibr Per Fld	.005	.015	.345	.01	.30
Fibr Cnt Fibr Per CC	< 0.0015	< 0.0015	0.0094	< 0.0015	0.0082
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




CITY_DEP_WORBY_CANNATA_SUBP_000021167

AIRTEK ENVIRONMENTAL CORP	Date: 12/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 172 Code: JG
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	JG -1221-06	JG -1221-	JG -1221-	JG -1221-	JG -1221-
Location	IWA, 14TH FL. TRANSFORMER RM 120 CHURCH				
Activity	DURING ABATEMENT				
Personal	- - -				
Avg Flow	15.0	0.0	0.0	0.0	0.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	08:40P				
Time Off	10:40P				
Tot Time	120 min				
Tot Vol	1800 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.215				
Fibr Cnt Fibr Per CC	0.0059				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




AIRTEK ENVIRONMENTAL CORP	Date: 12/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 173 Code: JG
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip:		
Date Analyzed: 12/22/01		

Sample	JG -1221-07	JG -1221-08	JG -1221-09	JG -1221-10	JG -1221-11
Location	IWA,12TH FL. TRANSFORMER RM W.SIDE OF RM 110 CHURCH	IWA,12TH FL. TRANSFORMER RM W.SIDE OF RM 110 CHURCH	IWA,12TH FL. E.SIDE TRANSFORMER RM 120 CHURCH	IWA,12TH FL. ADJ. TO EAST SIDE TRANSF. ROOM	IWA,14TH FL. E.SIDE TRANSF 110 CHURCH
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- - -				
Avg Flow	15.0	15.0	15.0	15.0	15.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	08:50P	08:50P	08:52P	08:52P	09:00P
Time Off	10:50P	10:50P	10:52P	10:52P	11:00P
Tot Time	120 min	120 min	120 min	120 min	120 min
Tot Vol	1800 ltr	1800 ltr	1800 ltr	1800 ltr	1800 ltr
AV Cnt Fibr Per Fld	.025	.505	.06	.24	.215
Fibr Cnt Fibr Per CC	< 0.0015	0.0138	0.0016	0.0065	0.0059
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP	Date: 12/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 174 Code: JG
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	JG -1221-12	JG -1221-	JG -1221-	JG -1221-	JG -1221-
Location	IWA, 14TH FL. E. SIDE TRANSF. 110 CHURCH				
Activity	DURING ABATEMENT				
Personal	- - -				
Avg Flow	15.0	0.0	0.0	0.0	0.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	09:00P				
Time Off	11:00P				
Tot Time	120 min				
Tot Vol	1800 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.095				
Fibr Cnt Fibr Per CC	0.0026				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




AIRTEK ENVIRONMENTAL CORP	Date: 12/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 175 Code: JG
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	JG -1221-13	JG -1221-14	JG -1221-15	JG -1221-16	JG -1221-17
Location	IWA,16TH FL. 110 CHURCH ST TRANSF. ROOM	IWA,16TH FL. 110 CHURCH ST TRANSF. ROOM	IWA,10TH FL. 110 CHURCH ST TRANSF. ROOM	IWA,10TH FL. 110 CHURCH ST TRANSF. ROOM	IWA,10TH FL. 120 CHURCH ST TRANSF.ROOM
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- - -				
Avg Flow	15.0	15.0	15.0	15.0	15.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	11:10A	11:10A	11:20A	11:20A	11:22A
Time Off	01:10P	01:10P	01:20P	01:20P	01:22P
Tot Time	120 min	120 min	120 min	120 min	120 min
Tot Vol	1800 ltr	1800 ltr	1800 ltr	1800 ltr	1800 ltr
AV Cnt Fibr Per Fld	.12	.13	.405	.035	.285
Fibr Cnt Fibr Per CC	0.0033	0.0035	0.0110	< 0.0015	0.0078
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




CITY_DEP_WORBY_CANNATA_SUBP_000021171

AIRTEK ENVIRONMENTAL CORP	Date: 12/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 176 Code: JG
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	JG -1221-18	JG -1221-	JG -1221-	JG -1221-	JG -1221-
Location	IWA, 10TH FL. 120 CHURCH ST TRANSF. RM				
Activity	DURING ABATEMENT				
Personal					
Avg Flow	15.0	0.0	0.0	0.0	0.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	11:22A				
Time Off	01:22P				
Tot Time	120 min				
Tot Vol	1800 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.115				
Fibr Cnt Fibr Per CC	0.0031				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




AIRTEK ENVIRONMENTAL CORP	Date: 12/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 177 Code: JG
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	JG -1221-19	JG -1221-20	JG -1221-21	JG -1221-22	JG -1221-23
Location	IWA, 8TH FL. 110 CHURCH ST TRANSF. ROOM	IWA, 8TH FL. 110 CHURCH ST TRANSF. ROOM	IWA, 8TH FL. 120 CHURCH ST TRANSF. ROOM	IWA, 8TH FL. 120 CHURCH ST TRANSF. ROOM	IWA, 6TH FL. 110 CHURCH ST TRANSF. ROOM
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal					
Avg Flow	15.0	15.0	15.0	15.0	15.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	12:10P	12:10P	12:15P	12:15P	12:30P
Time Off	02:10P	02:10P	02:15P	02:15P	02:30P
Tot Time	120 min	120 min	120 min	120 min	120 min
Tot Vol	1800 ltr	1800 ltr	1800 ltr	1800 ltr	1800 ltr
AV Cnt Fibr Per Fld	.045	.045	.005	.03	.005
Fibr Cnt Fibr Per CC	< 0.0015	< 0.0015	< 0.0015	< 0.0015	< 0.0015
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




CITY_DEP_WORBY_CANNATA_SUBP_000021173

AIRTEK ENVIRONMENTAL CORP	Date: 12/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 178 Code: JG
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	JG -1221-24	JG -1221-	JG -1221-	JG -1221-	JG -1221-
Location	IWA, 6TH FL. 110 CHURCH ST TRANSF. ROOM				
Activity	DURING ABATEMENT				
Personal					
Avg Flow	15.0	0.0	0.0	0.0	0.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	12:30P				
Time Off	02:30P				
Tot Time	120 min				
Tot Vol	1800 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.075				
Fibr Cnt Fibr Per CC	0.0020				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




CITY_DEP_WORBY_CANNATA_SUBP_000021174

AIRTEK ENVIRONMENTAL CORP	Date: 12/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 179 Code: JG
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	JG -1221-25	JG -1221-26	JG -1221-27	JG -1221-28	JG -1221-29
Location	IWA, 6TH FL. 120 CHURCH ST TRANSF. ROOM	IWA, 6TH FL. 120 CHURCH ST TRANSF. ROOM	IWA, 4TH FL. 110 CHURCH ST TRANSF. ROOM	IWA, 4TH FL. 110 CHURCH ST TRANSF. ROOM	IWA, 4TH FL. 120 CHURCH ST TRANSF. ROOM
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal					
Avg Flow	15.0	15.0	15.0	15.0	15.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	01:00P	01:00P	01:10P	01:10P	01:15P
Time Off	03:00P	03:00P	03:10P	03:10P	03:15P
Tot Time	120 min	120 min	120 min	120 min	120 min
Tot Vol	1800 ltr	1800 ltr	1800 ltr	1800 ltr	1800 ltr
AV Cnt Fibr Per Fld	.015	.04	.075	.11	.02
Fibr Cnt Fibr Per CC	< 0.0015	< 0.0015	0.0020	0.0030	< 0.0015
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




CITY_DEP_WORBY_CANNATA_SUBP_000021175

AIRTEK ENVIRONMENTAL CORP	Date: 12/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 180 Code: JG
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip:		
Date Analyzed: 12/22/01		

Sample	JG -1221-30	JG -1221-	JG -1221-	JG -1221-	JG -1221-
Location	IWA, 4TH FL. 120 CHURCH ST TRANSF. ROOM				
Activity	DURING ABATEMENT				
Personal					
Avg Flow	15.0	0.0	0.0	0.0	0.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	01:15P				
Time Off	03:15P				
Tot Time	120 min				
Tot Vol	1800 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.015				
Fibr Cnt Fibr Per CC	< 0.0015				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




AIRTEK ENVIRONMENTAL CORP	Date: 12/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 181 Code: JG
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip:		
Date Analyzed: 12/22/01		

Sample	JG -1221-31	JG -1221-32	JG -1221-33	JG -1221-34	JG -1221-35
Location	IWA, 3RD FL. 110 CHURCH ST TRANSF. ROOM	IWA, 3RD FL. 110 CHURCH ST TRANSF. ROOM	FIELD BLANK	FIELD BLANK	FIELD BLANK
Activity	DURING ABATEMENT	DURING ABATEMENT	Other	Other	Other
Personal			- -	- -	- -
Avg Flow	15.0	15.0	0.0	0.0	0.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	01:30P	01:30P			
Time Off	03:30P	03:30P			
Tot Time	120 min	120 min			
Tot Vol	1800 ltr	1800 ltr	0000000000	0000000000	0000000000
AV Cnt Fibr Per Fld	.015	.065	BDL	BDL	BDL
Fibr Cnt Fibr Per CC	< 0.0015	0.0018			
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



CITY_DEP_WORBY_CANNATA_SUBP_000021177

AIRTEK ENVIRONMENTAL CORP	Date: 12/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 182 Code: JG
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	JG -1221-36	JG -1221-	JG -1221-	JG -1221-	JG -1221-
Location	FIELD BLANK				
Activity	Other				
Personal	- -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt Fibr Per Fld	BDL				
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

