

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Benn Lewis
Airetek Environmental Corporation
39 W. 38th Street
New York, NY 10018

Received: 12/15/01 7:00:00 AM

ATC Group #: 6115

Analysis Date: 12/15/01

Fax: (212) 768-0759 Phone: (212) 768-0516

Project: Lions Head 110 Development LLC
110-120 Church

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5µ	5µ		(S/mm ²)	(S/cc)	
01 6115 -1	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
02 6115 -2	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
03 6115 -3	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
04 6115 -4	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.8		
05 6115 -5	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.8		
06 6115 -6	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.8		
07 6115 -7	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.8		
08 6115 -8	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.8		

12/15/01 TEM

30 ALLG

MARK PEYSAKHOV

Analyzed by:

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_DEP_WORBY_CANNATA_SUBP_000021205