

ATC Associates Inc.104 E. 25th St., 10th Floor, New York, NY 10010-2917
(212) 353-8280 Fax (212) 353 8306**Air Samples Phase Contrast Microscopy (PCM) Results**

Client Name : Airttek Environmental Corp.
 Client No. : 15495
 Project Name : EM&CA/Lions Head Develop.
 Project No. : 15495-3041
 Project Address: Lions Head Development
 53 Park Place, NY

Page : 1
 ELAP No. : 10879
 NVLAP No. : 1187
 Microscope #: NYC0643
 Method : NIOSH 7400/A Rules
 Revision #3

Sample No.	Batch No.	Analyzed by	Sample Location			Type	Collect Date	Total Time	Flow Rate	Total Volume	Results
			Work Area	In/Out	Location						
282	6830	EE	53 Park Pl/3-4 floors	ISWA	4th fl, room J bedroom	Final	12/12/01	130	15.00	1950	<0.003
283	6830	EE	53 Park Pl/3-4 floors	ISWA	4th fl, room J kitchen	Final	12/12/01	130	15.00	1950	<0.003
284	6830	EE	53 Park Pl/3-4 floors	ISWA	4th fl, room K bathroom	Final	12/12/01	130	15.00	1950	<0.003
285	6830	EE	53 Park Pl/3-4 floors	ISWA	4th fl, room K kitchen	Final	12/12/01	130	15.00	1950	<0.003
286	6830	EE	53 Park Pl/3-4 floors	ISWA	4th fl, room K living room	Final	12/12/01	130	15.00	1950	<0.003
287	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room A living room	Final	12/12/01	130	15.00	1950	<0.003
288	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room A bathroom	Final	12/12/01	130	15.00	1950	<0.003
289	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room A living room NW	Final	12/12/01	130	15.00	1950	<0.003
290	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room B living room	Final	12/12/01	128	15.00	1920	<0.003
291	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room B bathroom	Final	12/12/01	128	15.00	1920	<0.003
292	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room C living room	Final	12/12/01	128	15.00	1920	<0.003
293	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room C bedroom	Final	12/12/01	127	15.00	1905	<0.003
294	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room C kitchen	Final	12/12/01	127	15.00	1905	<0.003
295	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room D living room	Final	12/12/01	128	15.00	1920	<0.003
296	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room D kitchen	Final	12/12/01	128	15.00	1920	<0.003
297	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room D bedroom	Final	12/12/01	128	15.00	1920	<0.003
298	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room E bathroom	Final	12/12/01	130	15.00	1950	<0.003
299	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room E kitchen	Final	12/12/01	130	15.00	1950	<0.003
300	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room E living room	Final	12/12/01	130	15.00	1950	<0.003
301	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room F kitchen	Final	12/12/01	130	15.00	1950	<0.003
302	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room F living room	Final	12/12/01	130	15.00	1950	<0.003
303	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room F bedroom	Final	12/12/01	130	15.00	1950	<0.003
304	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room G living room	Final	12/12/01	130	15.00	1950	<0.003
305	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room G bedroom	Final	12/12/01	130	15.00	1950	<0.003
306	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room G kitchen	Final	12/12/01	130	15.00	1950	<0.003
307	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room H kitchen	Final	12/12/01	130	15.00	1950	<0.003
308	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room H living room	Final	12/12/01	130	15.00	1950	<0.003
309	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room H bedroom	Final	12/12/01	130	15.00	1950	<0.003

LEGEND

- OSWA - Outside Work Area
- ISWA - Inside Work Area
- Min. - Time In Minutes
- c.c. - Cubic Centimeter
- L - Liters
- F - Fibers
- PEL - Permissible Exposure Limit

• *Results are in actual Fibers/c.c. or as limit of quantitation whichever is higher.

Note - Action criteria for area samples is 0.01 fibers/c.c.
 - For personal samples, PEL(OSHA) is 0.1 fibers/c.c.


 Laboratory Director / Approved Signatory

CITY_21NC100_002861598

ATC Associates Inc.104 E. 25th St., 10th Floor, New York, NY 10010-2917
(212) 353-8280 Fax (212) 353 8306**Air Samples Phase Contrast Microscopy (PCM) Results**

Client Name : Airtek Environmental Corp.
 Client No. : 15495
 Project Name : EM&CA/Lions Head Develop.
 Project No. : 15495-3041
 Project Address: Lions Head Development
 53 Park Place, NY

Page : 2
 ELAP No. : 10879
 NVLAP No. : 1187
 Microscope #: NYC0643
 Method : NIOSH 7400/A Rules
 Revision #3


Sample No.	Batch No.	Analyzed by	Sample Location			Type	Collect Date	Total Time	Flow Rate	Total Volume	Results
			Work Area	In/Out	Location						
310	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room I living room	Final	12/12/01	130	15.00	1950	<0.003
311	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room I bedroom	Final	12/12/01	130	15.00	1950	0.004
312	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room I kitchen	Final	12/12/01	130	15.00	1950	<0.003
313	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room J living room	Final	12/12/01	132	15.00	1980	<0.003
314	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room J kitchen	Final	12/12/01	132	15.00	1980	<0.003
315	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room J bathroom	Final	12/12/01	132	15.00	1980	<0.003
316	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room K bedroom	Final	12/12/01	133	15.00	1995	<0.003
317	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room K living room	Final	12/12/01	133	15.00	1995	<0.003
318	6830	EE	53 Park Pl/3-4 floors	ISWA	3rd fl, room K kitchen	Final	12/12/01	133	15.00	1995	<0.003
319	6830	EE	53 Park Pl/3-4 floors	OSWA	3rd fl, by elevator	Final	12/12/01	134	15.00	2010	<0.002
320	6830	EE	53 Park Pl/3-4 floors	OSWA	3rd fl, by exit B	Final	12/12/01	134	15.00	2010	<0.002
321	6830	EE	53 Park Pl/3-4 floors	OSWA	3rd fl, by exit A	Final	12/12/01	134	15.00	2010	<0.002
322	6830	EE	53 Park Pl/3-4 floors	OSWA	3rd fl, corridor N	Final	12/12/01	136	15.00	2040	<0.002
323	6830	EE	53 Park Pl/3-4 floors	OSWA	3rd fl, corridor S	Final	12/12/01	136	15.00	2040	<0.002

LEGEND

- * OSWA - Outside Work Area
- ISWA - Inside Work Area
- Min. - Time in Minutes
- c.c. - Cubic Centimeter
- L - Liters
- F - Fibers
- PEL - Permissible Exposure Limit

****Results are in actual Fibers/c.c. or as limit of quantitation whichever is higher.**

Note - Action criteria for area samples is 0.01 fibers/c.c.
 - For personal samples, PEL(OSHA) is 0.1 fibers/c.c.


 Laboratory Director / Approved Signatory

CITY_21MC100_002861599