

SciLab Job #: 201092289

Client Name: Colden Corporation

Table I
Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)

01204; Pace University; 1 Pace Plaza - Manhattan, NY Campus

SciLab Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)			Structure Density (struc/sq. mm.)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>5.0	Total	>5.0	Total	>5.0	Total	
15	01204-54		1338	.06	0.0048	0.0	0.0	0.0	<16.7	<16.7	<0.0048	<0.0048	NSD
	1st Floor/ West Tower Lobby By Security Desk North Lobby Unit												
16	01204-55		1270	.07	0.0043	0.0	0.0	0.0	<14.3	<14.3	<0.0043	<0.0043	NSD
	B-Level/ West Tower Student Union By Door To Meeting Rm "B" #AC-9												
17	01204-56		1355	.06	0.0047	0.0	0.0	0.0	<16.7	<16.7	<0.0047	<0.0047	NSD
	C-Level/ Gymnasium NE Side												

* concentration represented by the detection of 1 structure

** not analyzed

NSD: No Asbestos Structures Detected

Reviewed By:



; Analyzed By:


 Aleksandr Barengolts

Date: 9/19/01

NVLAP#: 200546-0

CITY_21MC100_002849917