

Asbestos TEM Air Monitoring Summary

Face Manhattan Campus	Date:	Asbestos (structures/s sq. mm) EPA Less than 10 structures	Face Manhattan Campus	Date:	Asbestos (structures /sq. mm) EPA Less than 10 structures	Face Manhattan Campus	Date:	Asbestos (structures /sq. mm) EPA Less than 10 structures
Standards:			Standards:			Standards:		
16th Floor	10/12/01	<7.1	4th Floor	10/09/01	ND	14th Floor	01/10/02	<14.3
4th Floor	10/12/01	<14.3	6th Floor	10/09/01	ND	4th Floor-Roof	01/10/02	<14.3
Roof	10/12/01	<11.1	11th Floor East	10/12/01	<20	2nd Floor	01/11/02	<20
4th Floor	10/22/01	<12.5	2nd Floor	10/12/01	<20	4th Floor-Roof	01/11/02	<16.7
Roof	10/22/01	<9.1	6th Floor East	10/12/01	<20	10th Floor	01/15/02	<16.7
11th Floor	10/24/01	<14.3	8th Floor East	10/12/01	<16.7	4th Floor-Roof	01/15/02	<16.7
Roof	10/24/01	<14.3	4th Floor West	10/12/01	<20	11th Floor	01/17/02	<14.3
8th Floor	10/26/01	<16.7	15th Floor	10/12/01	<20	4th Floor-Roof	01/17/02	<16.7
Roof	10/26/01	<14.3	8th Floor	10/22/01	<16.7	12th Floor	01/18/02	<14.3
10th Floor	10/29/01	<12.5	6th Floor	10/24/01	<12.5	4th Floor-Roof	01/18/02	<14.3
Roof	10/29/01	<12.5	7th Floor	10/26/01	<12.5	4th Floor-Roof	01/23/02	<10
15th Floor	10/31/01	<10	5th Floor	10/29/01	<11.1	13th Floor	01/23/02	<10
Roof	10/31/01	<10	11th Floor	11/29/01	<10	14th Floor	01/31/02	<10
14th Floor	11/01/01	<9.1	4th Floor - Roof	11/29/01	<10	4th Floor-Roof	01/31/02	<10
Roof	11/01/01	<12.5	8th Floor	11/30/01	<10	17th Floor	02/08/02	<14.3
13th Floor	11/03/01	<11.1	4th Floor - Roof	11/30/01	<10	4th Floor Roof	02/08/02	<16.7
Roof	11/03/01	37.50	6th Floor	12/04/01	<10	16th Floor	02/11/02	<14.3
15th Floor	11/08/01	10.00	4th Floor - Roof	12/04/01	<10	4th Floor-Roof	02/11/02	<16.7
Roof	11/08/01	<12.5	7th Floor	12/05/01	<10	7th Floor	02/14/02	<16.7
9th Floor	11/09/01	<10	4th Floor - Roof	12/05/01	<10	4th Floor-Roof	02/14/02	<16.7
Roof	11/09/01	<11.1	9th Floor	12/06/01	<10	9th Floor	02/15/02	<14.3
12th Floor	11/13/01	<12.5	4th Floor - Roof	12/06/01	<10	4th Floor-Roof	02/15/02	<14.3
2nd Floor	11/14/01	<11.1	16th Floor	12/10/01	<10	10th Floor	02/19/02	<16.7
			4th Floor-Roof	12/10/01	<10	4th Floor-Roof	02/19/02	<16.7
			10th Floor	12/11/01	<10	13th Floor	02/21/02	<16.7
			4th Floor-Roof	12/11/01	<10	4th Floor-Roof	02/21/02	<14.3
			5th Floor	12/12/01	10	15th Floor	02/22/02	<16.7
			4th Floor-Roof	12/12/01	<10	4th Floor	02/22/02	<14.3
			4th Floor-Roof	12/18/01	<11.1			
			5th Floor	12/18/01	<16.7			
			12th Floor	12/20/01	<14.3			
			4th Floor-Roof	12/20/01	<12.5			
			4th Floor-Roof	12/27/01	<12.5			
			B level	12/27/01	<14.3			
			4th Floor-Roof	12/28/01	<14.3			
			1st Floor	12/28/01	<12.5			
			16th Floor	01/03/02	<16.4			
			4th Floor-Roof	01/03/02	<14.3			
			13th Floor	01/04/02	<16.7			
			4th Floor-Roof	01/04/02	<20			
			3rd Floor	01/09/02	<20			
			4th Floor-Roof	01/09/02	<16			

Golden Corporation
CPN: 01204

2/02