

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Ben Sallemi
ATC Associates Inc
104 East 25th Street
New York NY 10010

Received: 11/17/01 8:00:00 AM**ATC Group #:** 5907**Analysis Date:** 11/19/01**Fax:** (212) 353-8306 **Phone:** (212) 353-8280

Project: 225 Rector Place
225 Rector Place

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5μ-5 μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	Notes
1 - 5907 -1	1300.00	0.0674	0	None Detected	0 0	0.0044	<14.83 <0.0044	
2 - 5907 -2	1300.00	0.0674		Not Analyzed		0.0044		Missing Filter
3 - 5907 -3	1300.00	0.0674	0	None Detected	0 0	0.0044	<14.83 <0.0044	
4 - 5907 -4	1300.00	0.0674	0	None Detected	0 0	0.0044	<14.83 <0.0044	
5 - 5907 -5	1300.00	0.0674	0	None Detected	0 0	0.0044	<14.83 <0.0044	
6 - 5907 -6	1300.00	0.0674	0	None Detected	0 0	0.0044	<14.83 <0.0044	
7 - 5907 -7	1300.00	0.0674	0	None Detected	0 0	0.0044	<14.83 <0.0044	
8 - 5907 -8	1300.00	0.0674	0	None Detected	0 0	0.0044	<14.83 <0.0044	

MICHAEL GORYCKI

Analyzed by:

MICHAEL A. GORYCKI, Ph.D

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

8