

Attn: F. Burkhard
ATC Associates Inc
104 East 25th Street
New York NY 10010

Received: 11/1/01 8:00:00 AM

ATC Group #: 5802

Analysis Date: 11/1/01

Fax: (212) 353-8306 Phone: (212) 353-8280

Project: Parc Plase
225 Rector Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
12 - 5802 -9	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
13 - 5802 -10	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
14 - 5802 -11	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
15 - 5802 -12	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
16 - 5802 -13	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
17 - 5802 -14	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
18 - 5802 -15	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
19 - 5802 -16	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
20 - 5802 -17	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
21 - 5802 -18	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044

ROMAN PEYSAKHOV

Analyzed by

R. Ruy

MICHAEL A. GORYCKI, Ph D

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879