

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306

**Attn:** Mr. Fred Burkhardt

ATC Associates Inc

104 East 25th Street

New York

NY 10010

Fax: (212) 353-8306**Phone:** (212) 353-8280**Received:** 11/16/01 8:00:00 AM**ATC Group #:** 5901**Analysis Date:** 11/16/01**Project:** 225 Rector Place

225 Rector Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5µ-5 µ	5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
1 - 5901 -1	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
2 - 5901 -2	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
3 - 5901 -3	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
4 - 5901 -4	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
5 - 5901 -5	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
6 - 5901 -6	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
7 - 5901 -7	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
8 - 5901 -8	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	

ROMAN PEYSAKHOV

Analyzed by

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879