

SciLab Job #: 201092755
 Client Name: Parker House Services, Inc.

Table I
Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)
PHS01007; 327 Rector, 99 Battery Place, 200 Rector, 380 Rector Place / AMBIENT

SciLab Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)			Structure Density (struc/sq. mm.)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>5.0	Total	>5.0	Total	>5.0	Total	
01	J109.22.01-01 Inside Lobby Near Elevator 99 Battery Place		1300	.06	0.0049	0.0	0.0	0.0	<16.7	<16.7	<0.0049	<0.0049	NSD
02	J109.22.01-02 99 Battery Place Outside Building		1300	.06	0.0049	0.0	0.0	0.0	<16.7	<16.7	<0.0049	<0.0049	NSD
03	J109.22.01-03 99 Battery Place Inside Milford Manag. Office		1300	.06	0.0049	0.0	0.0	0.0	<16.7	<16.7	<0.0049	<0.0049	NSD
04	J109.22.01-04 99 Battery Place Inside Corridor 4th Floor		1300	.06	0.0049	0.0	0.0	0.0	<16.7	<16.7	<0.0049	<0.0049	NSD
05	J109.22.01-05 380 Rector Place Inside Lobby		1300	.06	0.0049	0.0	0.0	0.0	<16.7	<16.7	<0.0049	<0.0049	NSD
06	J109.22.01-06 380 Rector Place Outside Building		1300	.06	0.0049	0.0	0.0	0.0	<16.7	<16.7	<0.0049	<0.0049	NSD
07	J109.22.01-07 200 Rector Place Inside Lobby		1300	.06	0.0049	1.0	0.0	1.0	<16.7	16.7	<0.0049	0.0049	chrysotile
08	J109.22.01-08 200 Rector Place Outside Building		1300	.06	0.0049	0.0	0.0	0.0	<16.7	<16.7	<0.0049	<0.0049	NSD
09	J109.22.01-09 377 Rector Place Inside Lobby		1300	.06	0.0049	0.0	0.0	0.0	<16.7	<16.7	<0.0049	<0.0049	NSD
10	J109.22.01-10 377 Rector Place Outside Building		1300	.06	0.0049	0.0	0.0	0.0	<16.7	<16.7	<0.0049	<0.0049	NSD
11**	J109.22.01-11 Field Blank												
12**	J109.22.01-12 Field Blank												
13**	J109.22.01-13 Sealed Blank												

* concentration represented by the detection of 1 structure

** not analyzed

NSD: No Asbestos Structures Detected

Reviewed By: _____; Analyzed By: R. Pysakhov Date: 9/22/01

Roman Pysakhov

NVLAP#: 200546-0

[TX/RX NO 9918]

09/25/01 TUE 08:58

CITY_21MC100_002850436

FROM PARKER HOUSE SERVICE 9143374955

9-25-2001 8:01AM