

10/12/2001 14:34 7329810551

EMSL ANALYTICAL

PAGE 01/02

EMSL Analytical, Inc.

1058 Stelton Road, Piscataway, NJ 08854

Phone: 732-981-0550 Fax: 732-981-0551 Email:

EMSL

Attn: George Russell
Environmental Monitoring & Consulting
(EM & CA)
P.O. Box 872
Somerville, NJ 08876

Fax: (732) 249-3384

Phone: 732-249-3005

Project: 88 Greenwich St. Manhattan

Customer ID: EMCA50

Customer PO:

Received: 10/12/01 9:00 AM

EMSL Order: 050102754

EMSL Project ID:

Analysis Date: 10/12/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)	Notes
001 50102754-0001	1920.00	0.0500	1	None Detected		0.0040	<20.00 <0.0040	
002 050102764-0002	1200.00	0.0750	5	None Detected		0.0043	<13.33 <0.0043	
003 050102754-0003	1440.00	0.0625	1	None Detected		0.0043	<16.00 <0.0043	
004 50102754-0004	1200.00	0.0750	2	None Detected		0.0043	<13.33 <0.0043	
005 050102754-0005	1200.00	0.0750	4	None Detected		0.0043	<13.33 <0.0043	
006 050102754-0006	1440.00	0.0625	1	None Detected		0.0043	<16.00 <0.0043	

Drew Hodgden

Analyst



Adrian Arav
or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Analysis performed by EMSL Piscataway (NY State ELAP #11423, NVLAP #101D48-2, Connecticut DOH PH-0268 Approved Env. Lab)

TEMAHERA-1

1