

EMSL Analytical, Inc.

1058 Stelton Road, Piscataway, NJ 08854

Phone: 732-981-0550 Fax: 732-981-0551 Email:

EMSL

Attn: George Russell
Environmental Monitoring & Consulting
(EM & CA)
P.O. Box 872
Somerville, NJ 08876
Fax (732) 249-3384
Project 88 Greenwich Street

Phone: 732-249-3005

Customer ID: EMCA50
Customer PQ:
Received: 10/26/01 1:10 PM
EMSL Order: 050103045
EMSL Project ID:
Analysis Date: 10/27/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
01 50103045-0001	1440.00	0.0625	5	None Detected		0.0043	<16.00 <0.0043	
002 50103045-0002	1440.00	0.0625	39	None Detected		0.0043	<16.00 <0.0043	
003 50103045-0003	1440.00	0.0625	3	None Detected		0.0043	<16.00 <0.0043	
004 50103045-0004	1440.00	0.0625	6	None Detected		0.0043	<16.00 <0.0043	
005 50103045-0005	1440.00	0.0625	1	None Detected		0.0043	<16.00 <0.0043	

Filter pore size 0.80 micron.

Drew Hodgden

Analyst

Adrian Arav
Adrian Arav
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Analysis performed by EMSL Piscataway (NY State ELAP #11423, NVLAP #101048-2, Connecticut DOH PH-0266 Approved Env. Lab)

TEMAHERA-1

1