

EMSL Analytical, Inc.

1056 Stelton Road, Piscataway, NJ 08854

Phone: 732-981-0550 Fax: 732-981-0551 Email:

EMSL

Attn: George Russell
Environmental Monitoring & Consulting
(EM & CA)
P.O. Box 872
Somerville, NJ 08876

Fax: (732) 249-3384

Phone: 732-249-3005

Project: 88 Greenwich St. NY

Customer ID: EMCA50

Customer PO:

Received: 11/19/01 5.45 PM

EMSL Order: 050103552

EMSL Project ID:


Analysis Date: 11/21/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
001 7103552-0001	1280.00	0.0625	0	None Detected		0.0048	<16.00 <0.0048	
002 050103552-0002	1280.00	0.0625	0	None Detected		0.0048	<16.00 <0.0048	
3 050103552-0003	1280.00	0.0625	0	None Detected		0.0048	<16.00 <0.0048	
14 0103552-0004	1280.00	0.0625	0	None Detected		0.0048	<16.00 <0.0048	
005 0103552-0005	1280.00	0.0625	0	None Detected		0.0048	<16.00 <0.0048	

Drew Hodgden

Analyst


Adrian Arav
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Analysis performed by EMSL Piscataway (NY State ELAP #11423, NVLAP #101045-2, Connecticut DOH PH-0266 Approved Env. Lab)

TEMAHERA-1

1