

EMSL Analytical, Inc.

1056 Stelton Road, Piscataway, NJ 08854

Phone: 732-981-0550 Fax: 732-981-0551 Email:

EMSL

Attn: George Russell
Environmental Monitoring & Consulting
(EM & CA)
P.O. Box 872
Somerville, NJ 08876

Fax: (732) 249-3384

Phone: 732-249-3005

Project: 88 Greenwich

Customer ID: EMCA50

Customer PO

Received: 12/28/01 9:00 AM

EMSL Order: 050104047


EMSL Project ID

Analysis Date: 12/31/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
88-21-001 050104047-0001	1200.00	0.0750	2	None Detected		0.0043	<13.33 <0.0043	
88-21-002 050104047-0002	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	
88-21-003 050104047-0003	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	
88-21-004 050104047-0004	1200.00	0.0750	1	None Detected		0.0043	<13.33 <0.0043	
88-21-005 050104047-0005	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	
88-21-006 050104047-0006	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	
88-21-007 050104047-0007	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	
88-21-008 050104047-0008	1200.00	0.0750	1	None Detected		0.0043	<13.33 <0.0043	
88-21-009 050104047-0009	1200.00	0.0750	1	None Detected		0.0043	<13.33 <0.0043	
88-21-010 050104047-0010	1200.00	0.0750	1	Chrysotile	1 0	0.0043	13.33 0.0043	

Filter Pore Size 0.8 Microns.



Drew Hodgden (10)


Adrian Arav
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/loc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Analysis performed by EMSL Piscataway (NY State ELAP #11423, NVLAP #101048-2, Connecticut DOH PH-0266 Approved Env. Lab)

TEMAHERA-1

1