

EMSL Analytical, Inc.

1056 Stelton Road, Piscataway, NJ 08854

Phone: 732-981-0550 Fax: 732-981-0561 Email:

EMSL

Attn: George Russell
Environmental Monitoring & Consulting
(EM & CA)
P.O. Box 872
Somerville, NJ 08876

Fax: (732) 249-3384
Project: 88 Greenwich

Phone: 732-249-3005

Customer ID: EMCA50
Customer PO:
Received: 01/24/02 5:40 PM

EMSL Order: 050200344
EMSL Project ID:
Analysis Date: 1/29/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
8823001 050200344-0001	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
8823002 050200344-0002	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
8823003 050200344-0003	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
8823004 050200344-0004	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
8823005 050200344-0005	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
8823006 050200344-0006	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
8823007 050200344-0007	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
8823008 050200344-0008	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
8823009 050200344-0009	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
8823010 050200344-0010	1800.00	0.0500	0	Chrysotile	1 0	0.0043	20 0.0043	
8823011 050200344-0011	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	

Adrian Arav (12)

Adrian Arav
or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the sample reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Analysis is performed by EMSL Piscataway (NY State ELAP #11423, NVLAP #101048-2, Connecticut DOH PH-0266 Approved Env. Lab)

TEMAHERA-1

1

EMSL Analytical, Inc.

1056 Stelton Road, Piscataway, NJ 08854

Phone: 732-981-0550 Fax: 732-981-0561 Email:

EMSL

Attn: Georga Russell
Environmental Monitoring & Consulting
(EM & CA)
P.O. Box 872
Somerville, NJ 08876

Fax: (732) 249-3384
Project: 88 Greenwich

Phone: 732-249-3005

Customer ID: EMCA50
Customer PO:
Received: 01/24/02 5:40 PM

EMSL Order: 050200344
EMSL Project ID:
Analysis Date: 1/29/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm³) (S/cc)	Notes
8823012	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	

050200344-0012

Adrian Arav (12)

Adrian Arav
or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by EMSL. The report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Analysis performed by EMSL Piscataway (NY State ELAP #11423, NVLAP #101048-2, Connecticut DOH PH-0266 Approved Env. Lab)

TEMAHERA-1

2