


TEM Asbestos (air) Count Sheetsample area
analyzedClient Name: GCI Environmental Advisory, Inc.Job #: 201092763Volume (liters): 900.0Lab Sample #: 02Filter Type / Filter Area: MCE 385 mm2Client Sample #: 22-25C-9/21-07Grid Opening Size: 0.01000Received: 09/22/2001

17:15:00

Area Examined: 0.10000 mm2Date Analyzed: 09/22/2001Magnification: 20,000Scope #:Accelerating Voltage: 100 KeV

Analysis Performed by: _____

Aleksandr Barengolts

Location	Grid Opening	Fiber	Length μM	Width μM	Fiber Type	Morphology	EDS	Orient	SAED	Photo
A9-3/3B	1	NSD								
A9-3/3C	2	NSD								
A9-3/3E	3	NSD								
A9-3/3F	4	NSD								
A9-3/3G	5	NSD								
A9-3/3H	6	NSD								
A9-3/3K	7	NSD								
A10-4/4B	8	NSD								
A10-4/4C	9	NSD								
A10-4/4E	10	NSD								

NSD: No Asbestos Structures Detected

Comments

		Structure Density	Concentration	<u>Grid Evaluation</u>
		(str/mm2)	(str/cc air)	
Total Grid Openings:	10			☒ Grid Openings Covered > 50% ☒ Intact Grid Opening > 50% ☒ Undissolved Filter < 10% ☒ Folded Replica < 50% ☒ Filter Loading < 10% ☒ Particulate Even
Chrysotile Asbestos Structures:	0	<10	<0.0043	
Amphibole Asbestos Structures:	0	<10	<0.0043	
Asbestos Structures ≥ 5 microns:	0	<10	<0.0043	
Total Non-Asbestos Structures:				
Total Asbestos Structures:	0	<10	<0.0043	
Analytical Sensitivity:		10	0.0043	

CITY_21MC100_002861810