

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax (212) 353-8306



Attn: Mr Joshua Sarett
ALC Environmental
115 W 30th Street
New York NY 10001

Received: 3/6/02 8 00 00 AM
ATC Group #: 6950
Analysis Date: 3/6/02

Fax (212) 279-6747 Phone: (212) 279-1001

Project: Gateway Plaza Management
375 Southard Ave., Bldg 200 NY, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	Notes
1 6950 -1	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048
2 6950 -2	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048
3 6950 -3	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048
4 6950 -4	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048
5 6950 -5	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048
6 6950 -6	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048
7 6950 -7	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048
8 6950 -8	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D

Approved by

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0 NY State ELAP #10879

Attn: Mr. Joshua Sarett
 ALC Environmental
 115 W 30th Street
 New York NY 10001

Received: 3/6/02 8 00:00 AM
 ATC Group #: 6950
 Analysis Date: 3/6/02

Fax: (212) 279-6747 Phone: (212) 279-1001

Project: Gateway Plaza Management
 375 Southold Ave., Bldg 200 NY, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
9 6950 -9	1800.00	0.0450	0	None Detected	0	0	0.0046	< 22.24	< 0.0048	
10 6950 -10	1800.00	0.0450	0	None Detected	0	0	0.0046	< 22.24	< 0.0048	

ROMAN PEYSAKHOV

Analyzed by



MICHAEL A. GORYCKI, Ph.D.

Approved by

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0 NY State ELAP #10879