

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Joshua Saren
ALC Environmental

115 W 30th Street

New York

NY 10001

Received: 1/10/02 7:00:00 AM

ATC Group #: 6298

Analysis Date: 1/10/02

Fax: (212) 279-6747

Phone: (212) 279-1001

Project: Gateway Plaza Management

375 South End Ave., Bldg. 100, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5µ-5 µ	Analynal Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
1 6298 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
2 6298 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
3 6298 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
4 6298 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
5 6298 -5	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
6 6298 -6	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
7 6298 -7	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
8 6298 -8	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048

ROMAN PEYSKHOV

Analyzed by

MICHAEL A. GORYCKI, Ph.D.

Approved by

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0 NY State ELAP #10879

Attn: Mr. Joshua Saret
ALC Environmental
115 W 30th Street
New York NY 10001

Received: 1/10/02 7:00:00 AM

ATC Group #: 6298

Analysis Date: 1/10/02

Fax: (212) 279-6747 Phone: (212) 279-1001

Project: Gateway Plaza Management
375 South End Ave., Bldg 100, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5µ	5µ		(S/mm ²)	(S/cc)	
9 6298-9	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
10 6298-10	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	

ROMAN PEYSAKHOV

Analyzed by

R. Pey

MICHAEL A. GORYCKI, Ph.D.

Approved by

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_DEP_WORBY_CANNATA_SUBP_000004141