

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Joshua Saret
ALC Environmental

115 W 30th Street

New York

NY 10001

Fax: (212) 279-6747

Phone: (212) 279-1001

Project: Gateway Plaza Management

355 South End Ave., Bldg. 400, New York, NY

Received: 1/17/02 6:00 00 AM

ATC Group #: 6355

Analysis Date: 1/17/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5µ-5 µ	Analytical Sensitivity (f/cc)	Asbestos Concentration (f/m.m ³) (f/cc)	Notes
1 6355 -1	1800.00	0.0450	0	None Detected	0 0	0.0048	<22.24 <0.0048	
2 6355 -2	1800.00	0.0450	0	None Detected	0 0	0.0048	<22.24 <0.0048	
3 6355 -3	1800.00	0.0450	0	None Detected	0 0	0.0048	<22.24 <0.0048	
4 6355 -4	1800.00	0.0450	0	None Detected	0 0	0.0048	<22.24 <0.0048	
5 6355 -5	1800.00	0.0450	0	None Detected	0 0	0.0048	<22.24 <0.0048	
6 6355 -6	1800.00	0.0450	0	None Detected	0 0	0.0048	<22.24 <0.0048	
7 6355 -7	1800.00	0.0450	0	None Detected	0 0	0.0048	<22.24 <0.0048	
8 6355 -8	1800.00	0.0450	0	None Detected	0 0	0.0048	<22.24 <0.0048	

ROMAN PEYSAKHOV

Analyzed by

MICHAEL A. GORYCKI Ph.D.

Approved by

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0 NY State ELAP #10879

Attn: Mr. Joshua Saret
ALC Environmental
115 W 30th Street
New York NY 10001

Fax: (212) 279-6747 Phone: (212) 279-1001

Project: Gateway Plaza Management
355 South End Ave., Bldg 400, New York NY

Received: 1/17/02 6 00 00 AM

ATC Group #: 6355

Analysis Date: 1/17/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5µ-5µ	Structures 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	Asbestos Concentration (S/cc)	Notes
9 6355 -9	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
10 6355 -10	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	

ROMAN PEYSAKHOV

Analyzed by

RRy

MICHAEL A. GORYCKI, Ph.D.

Approved by

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependant on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0 NY State ELAP #10879