

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page __ of ____

Time: 8:51 AM LOCATION: PS 851 DATE: 6/7/02 PROJECT NO: _____

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
OUTSIDE							
SOUTH EXIT	0	60.2	60.8	589	1	16	C
PLAY GROUND N	0	60.2	60.8	571	1	16	C
PLAY GROUND S	0	60.3	60.9	571	1	14	C
SE CORNER	0	60.2	60.9	585	1	15	C
EAST SIDE	0	60.1	60.9	610	1	16	C
N/W CORNER	0	60.1	60.9	660	1	12	C
NORTH EXIT	0	60.3	60.9	628	1	12	C
S/N CORNER	0	60.3	60.8	641	1	15	C
NEXT TO AIR INTAKE	0	60.3	60.8	650	1	15	C
NORTH CORNER	0	60.3	60.8	627	1	14	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 6/7/02

CITY_21MC100_002863346

Page of _____

PROJECT NO:

Comments:

Date: 6/7/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page __ of __

Time: 9:01 AM LOCATION: PS 87DATE: 6/7/02 PROJECT NO: _____

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
308	5	74.1	47.1	586	1	13	C
310	1	74.3	47.3	601	1	14	C
314 Hall	0	74.6	47.1	813	1	15	C
316	1	73.8	46.3	746	1	10	C
Hallway by Stair #12	0	73.7	46.1	558	1	9	C
326	20	73.4	46.1	603	1	14	C
328	10	73.7	46.6	803	1	16	C
330	21	74.0	48.1	949	1	9	C
314	0	73.8	46.5	571	1	11	C
332	1	74.1	47.5	881	1	8	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 6/7/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 10

Time: 10:16 AM LOCATION: PS 57

DATE: 6/7/02 PROJECT NO: _____

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
NEXT TO STAIR #4	0	138	49.1	558	1	12	0
219	22	73.9	49.1	1103	1	14	0
232	10	73.8	49.0	1043	1	10	0
230	15	73.8	49.1	1123	1	8	0
217 HALLWAY	0	73.8	48.6	641	1	11	0
228	20	73.6	47.6	548	1	11	0
276	0	73.9	47.8	714	1	12	0
477 HALLWAY	0	74.1	49.1	691	1	8	0
204	30	73.8	44.8	1131	1	10	0
202	25	73.8	47.8	874	1	10	0
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/7/02

CITY_21MC100_002863349

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 1 of 1

Time: 10:45 AM LOCATION: P-5 84

DATE: 6/7/02 PROJECT NO:

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
EASTSIDE of Room 208	6	74.0	47.1	591	1	11	0
EASTSIDE of Room 201	0	74.3	47.6	610	1	14	0
NEXT TO ELECTRICAL CLOSET 2ND FLOOR	0	73.8	48.6	616	1	12	0
INSIDE RM 206	0	73.9	49.1	701	1	8	0
NEXT TO RM 224	0	73.6	48.8	551	1	10	0
NEXT TO SOUTH SIDE of Room 211	1	73.5	48.6	599	1	10	0
NEXT TO Room 211	2	73.6	48.7	626	1	11	0
NEXT TO STAIRS #2 2ND FLOOR	0	73.9	48.6	657	1	10	0
SOUTH END of Hallway 2ND FLOOR	0	73.6	47.7	717	1	9	0
NORTH END of 2ND FLOOR Hallway	0	74.1	47.9	681	1	8	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/7/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 10

Time: 9:25 AM LOCATION: PS 81 DATE: 6/7/02 PROJECT NO: _____

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
301	10	74.6	46.8	606	1	15	C
301 Hallway	10	74.5	46.8	784	1	11	C
302	6	74.3	47.0	610	1	16	C
Hallway next to elevator bank	0	74.6	47.2	834	1	10	C
304	0	74.8	46.2	717	1	10	C
Hallway next to elevator bank	0	74.2	46.1	681	1	10	C
306	20	74.7	47.2	919	1	9	C
308 Hallway	0	74.8	47.7	916	1	13	C
315 Hallway	0	74.8	47.7	918	1	15	C
315 Gym	0	74.8	47.7	920	1	11	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 6/7/02

CITY_21MC100_002863351

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Time: 10:00 AM LOCATION: 175 5th DATE: 6/7/02 PROJECT NO:

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
NCX1 - 1C 5th Flr - 112 Hillway	0	71.8	51.0	731	1	9	0
526	25	70.4	53.5	1311	1	9	0
528	26	71.3	52.8	976	1	11	0
517	9	91.6	52.1	1012	1	14	0
550 Hillway	10	71.7	51.5	798	1	8	0
532	20	72.4	51.2	960	1	10	0
514	0	72.1	52.1	598	1	13	0
419	1	73.8	51.9	766	1	13	0
419 Hillway	5	73.8	51.9	782	1	14	0
432	0	73.8	52.0	603	1	10	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 6/7/02

CITY_21MC100_002863352

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 10

 Time: 6:31 AM LOCATION: 125 SGT

 DATE: 6/7/02 PROJECT NO:

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
430	1	73.9	51.2	834	1	12	C
428 HALLWAY	3	74.1	51.3	838	1	12	C
426	21	73.9	51.0	1122	1	11	C
HALLWAY BY STAIR#2	0	74.0	49.9	571	1	12	C
410 HALLWAY	1	74.0	49.8	626	1	14	C
408 HALLWAY	0	74.1	50.0	616	1	10	C
NEXT TO ELEVATOR BANK	0	74.0	50.0	601	1	9	C
404	1	74.2	49.1	615	1	11	C
401 HALLWAY	0	74.0	50.1	610	1	8	C
402	0	74.2	49.8	586	1	14	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

 Signature: [Signature] Date: 6/7/02