

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 1 of 3

Time: 5:00 AM LOCATION: PS 84 DATE: 6/10/02 PROJECT NO: 19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
OUTSIDE							
SOUTH EXIT	10	75.1	48.1	512	1	40	C
PLAY GROUND N	15	75.1	48.3	526	1	40	C
PLAY GROUND S	1	75.1	48.1	515	1	35	C
SE CORNER	0	75.1	48.1	531	1	38	C
EAST SIDE	6	75.1	48.1	530	1	40	C
N/W CORNER	2	75.4	48.3	531	1	39	C
NORTH EXIT	3	75.1	48.1	531	1	35	C
S/W CORNER	12	75.1	48.1	557	1	35	C
NEXT TO AIR INTAKE	0	75.4	48.1	553	1	38	C
NORTH CORNER	1	75.1	48.1	564	1	37	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 6/10/02

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 2 of 2

Time: 5:30 AM

LOCATION:

PS 89

DATE: 6/10/02 PROJECT NO: 19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
HALLWAY NEXT TO CAFETERIA	2	74.3	46.2	741	1	28	0
NORTH EXIT	1	74.6	46.3	699	1	26	0
DANCE ROOM	0	71.8	42.1	509	1	10	0
CAFETERIA	1	73.6	45.0	711	1	15	0
HALLWAY BY RM 126	0	74.2	46.3	710	1	16	0
132 A	1	71.0	47.1	507	1	16	0
132 B	2	71.3	47.6	510	1	22	0
132 C	0	71.4	47.2	610	1	30	0
132 D	0	72.1	47.1	649	1	20	0
SOUTH EXIT	0	74.2	46.5	740	1	20	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/10/02

**ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT**

Page 3 of 8

Time: 9:06 AM LOCATION: PS 89 DATE: 6/10/02 PROJECT NO: 19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
308	0	73.1	44.6	526	1	26	0
310	1	72.3	44.3	551	1	28	0
314 Hall	0	72.5	44.2	622	1	30	0
316	0	73.6	46.1	561	1	16	0
Hallway by Stair #12	0	72.9	44.3	601	1	17	0
326	25	73.6	46.3	1141	1	10	0
328	20	73.1	45.7	1026	1	15	0
330	25	73.3	45.7	1126	1	19	0
334	26	73.4	46.2	1149	1	18	0
332	28	73.6	47.1	1241	1	16	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 6/10/02

CITY_21MC100_002863361

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 18

Time: 9:20 AM LOCATION: PS 89 DATE: 6/10/02 PROJECT NO: 19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
301	0	73.2	47.6	559	1	17	0
301 Hallway	0	73.5	44.6	732	1	23	0
302	22	73.6	48.6	1026	1	19	0
Hallway next to elevator bank	0	73.6	44.6	609	1	26	0
304	10	73.1	44.2	959	1	25	0
Hallway next to elevator bank	0	73.6	44.6	629	1	20	0
306	15	72.9	43.7	1026	1	20	0
308 Hallway	0	73.9	44.9	709	1	19	0
315 Hallway	0	73.8	44.8	726	1	21	0
315 Gym	0	71.1	42.6	505	1	21	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/10/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 18

Time: 9:30 AM

LOCATION:

175 559 F1

DATE:

6/10/02

PROJECT NO:

19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
430	30	75.1	52.2	1410	1	24	0
428 Hallway	0	74.4	50.4	606	1	25	0
426	26	74.0	48.4	1376	1	19	0
HALLWAY BY STAIR#2	10	74.3	50.4	810	1	21	0
410 HALLWAY	0	74.2	50.6	599	1	21	0
408 HALLWAY	0	74.3	50.6	559	1	28	0
NEXT TO ELEVATOR BANK	0	74.6	50.9	601	1	25	0
404	25	74.1	46.9	1121	1	21	0
401 HALLWAY	0	74.1	51.1	626	1	22	0
402	23	74.2	47.0	1026	1	22	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:

Date:

6/10/02

CITY_21MC100_002863363

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 6 of 10

Time: 10:01 AM LOCATION: 175 St

DATE: 6/10/02 PROJECT NO: 19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
NEX 10 Stair 112 Hillw-14	0	72.3	50.6	578	1	20	0
526	0	73.0	49.6	621	1	19	0
528	25	73.1	49.8	915	1	22	0
517	7	73.3	50.2	815	1	19	0
550 Hillw-14	10	72.9	50.9	610	1	19	0
532	30	73.6	51.2	1189	1	16	0
514	0	73.9	51.1	631	1	16	0
419	1	74.1	52.3	1012	1	25	0
419 Hillw-14	3	72.9	50.9	636	1	26	0
432	25	75.0	56.4	1362	1	26	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: *[Signature]*

Date: 6/10/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 8

Time: 10:21 AM LOCATION: PS 59 DATE: 4/10/02 PROJECT NO: 19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
NEXT TO STAIR #4	0	73.2	45.8	641	1	24	0
219	0	73.1	45.9	710	1	19	0
232	28	73.1	46.2	993	1	21	0
230	10	73.4	47.6	832	1	22	0
217 Hallway	0	73.3	46.1	546	1	23	0
228	0	73.6	46.1	591	1	21	0
276	15	73.3	47.0	1001	1	21	0
AWITZIK	0	73.1	44.1	610	1	23	0
204	0	73.2	44.6	577	1	23	0
202	25	73.4	45.1	1241	1	23	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 4/10/02

CITY_21MC100_002863365

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 8

Time: 10⁴⁰ AM

LOCATION:

PS 84

DATE: 6/10/02 PROJECT NO: 19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
EAST SIDE OF ROOM 208	10	73.4	47.2	810	1	21	0
EAST SIDE OF ROOM 201	0	73.6	46.1	546	1	29	0
NEXT TO ELECTRICAL CLOSET 2ND FLOOR	0	73.6	46.2	601	1	19	0
INSIDE RM 206	0	73.5	46.2	599	1	20	0
NEXT TO RM 224	0	73.6	46.1	589	1	16	0
NEXT TO SOUTH SIDE OF ROOM 217	1	73.5	46.1	551	1	16	0
NEXT TO ROOM 211	3	73.4	46.3	509	1	14	0
NEXT TO STAIRS #2 4th Floor	0	73.3	46.1	551	1	29	0
SOUTH END OF Hallway 2nd Floor	0	73.3	46.1	526	1	30	0
NORTH END OF 2nd Floor Hallway	0	73.4	46.2	510	1	18	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: *Jim Thiel*

Date: 6/10/02