

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 1 of 8

Time: 8:00 AM LOCATION: PS 89

DATE: 6/24/02 PROJECT NO: 19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
OUTSIDE							
SOUTH EXIT	0	79.7	55.6	531	1	140	0
PLAY GROUND N	0	79.6	55.6	539	1	140	0
PLAY GROUND S	0	79.1	55.6	528	1	140	0
SE CORNER	3	78.9	55.8	536	1	140	0
EAST SIDE	1	79.7	55.4	540	1	140	0
N/W CORNER	0	78.8	55.3	555	1	136	0
NORTH EXIT	2	78.3	55.4	557	1	132	0
S/W CORNER	0	79.6	55.6	538	1	128	0
NEXT TO AIR INTAKE	10	79.4	55.6	567	1	136	0
NORTH CORNER	3	79.2	55.3	571	1	133	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/24/02

CITY_21MC100_002864704

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 2 of 8

Time: 8:30 AM LOCATION: PS 89

DATE: 6/24/02 PROJECT NO: 19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
HALLWAY NEXT TO CAFETERIA	3	76.1	49.9	626	1	59	0
NORTH EXIT	0	78.1	50.1	589	1	64	0
DANCE ROOM	3	73.1	50.1	710	1	61	0
CAFETERIA	26	74.7	48.6	589	1	41	0
HALLWAY BY RM 126	0	73.1	48.6	561	1	49	0
132 A	1	72.9	49.6	569	1	31	0
132 B	0	72.9	49.6	541	1	32	0
132 C	1	73.1	49.6	599	1	29	0
132 D	1	72.6	49.5	601	1	31	0
SOUTH EXIT	0	72.9	49.6	609	1	33	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/24/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 8Time: 9⁰⁰ AM LOCATION: PS 8^YDATE: 6/24/02 PROJECT NO: 19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
308	0	74.1	49.6	599	1	31	0
310	4	74.6	50.2	799	1	24	0
314 HALL	1	75.1	50.1	541	1	33	0
316	0	74.6	50.1	630	1	28	0
HALLWAY BY STAIR #2	0	74.9	50.6	526	1	36	0
326	20	73.9	49.9	858	1	22	0
328	23	73.6	48.9	991	1	26	0
330	14	73.9	48.9	1037	1	20	0
334	18	72.9	48.1	1068	1	19	0
332	22	72.6	48.6	1242	1	21	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 6/24/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 8

Time: 9:30 AM LOCATION: PS 59

DATE: 6/24/02 PROJECT NO: 19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
301	0	74.6	51.3	606	1	22	0
301 Hallway	0	73.9	50.2	581	1	19	0
302	20	76.2	53.6	989	1	14	0
Hallway next to elevator bank	0	74.1	49.6	566	1	26	0
304	12	76.4	52.6	947	1	30	0
Hallway next to elevator bank	0	73.6	49.1	571	1	29	0
306	1	76.3	51.9	621	1	28	0
308 Hallway	1	74.9	50.3	610	1	31	0
315 Hallway	2	74.6	51.1	631	1	32	0
315 Gym	0	72.1	46.1	599	1	27	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/24/02

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 5 of 8


Time: 9:50 AM LOCATION: PS SC

DATE: 6/24/02 PROJECT NO: 19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
NEXT TO STAIRWELL 1 HALLWAY	0	73.6	49.8	609	1	19	0
526	23	72.9	48.4	1247	1	20	0
528	26	72.6	48.3	1109	1	24	0
517	3	73.6	49.6	875	1	20	0
550 Hallway	1	73.9	49.3	616	1	19	0
532	30	73.3	49.3	1012	1	28	0
514	0	73.8	49.1	641	1	26	0
419	0	74.1	50.1	599	1	21	0
419 Hallway	1	74.3	50.6	630	1	22	0
432	0	72.9	48.9	609	1	23	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: 

Date: 6/24/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page ~~46~~ of ~~48~~ 8Time: 10¹⁰ AM LOCATION: PS 89 HDATE: 6/24/02 PROJECT NO: 19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
430	0	75.8	53.3	586	1	26	0
428 HALLWAY	1	73.8	50.3	615	1	20	0
426	7	75.1	52.1	813	1	26	0
HALLWAY BY STAIR #2	2	74.1	51.3	710	1	18	0
410 HALLWAY	3	74.3	51.1	731	1	19	0
408 HALLWAY	0	74.6	50.9	588	1	29	0
NEXT TO ELEVATOR BANK	0	73.9	50.1	591	1	32	0
404	28	75.9	51.2	1114	1	30	0
401 HALLWAY	0	74.6	50.9	571	1	26	0
402	0	75.6	50.9	586	1	22	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 6/24/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 108

Time: 10:30 AM LOCATION: PS 59

DATE: 6/24/02 PROJECT NO: 19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
NEXT TO STAIR #4	1	74.6	50.3	621	1	21	0
219	20	73.1	49.6	981	1	16	0
232	18	73.6	49.1	1026	1	18	0
230	22	74.1	50.1	1018	1	19	0
217 HALLWAY	1	75.5	51.6	644	1	26	0
228	0	74.1	50.4	614	1	23	0
226	0	73.6	48.6	609	1	20	0
AWITCZIK	3	72.1	47.1	741	1	24	0
204	0	72.9	47.1	601	1	19	0
202	3	72.8	46.6	826	1	20	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/24/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 8

Time: 10:51 AM

LOCATION: PS 89

DATE: 6/24/02 PROJECT NO: 19125-0297

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
EAST SIDE OF ROOM 208	7	74.1	50.1	809	1	22	0
EAST SIDE OF ROOM 201	0	73.1	49.9	581	1	19	0
NEXT TO ELECTRICAL CLOSET 2ND FLOOR	0	74.6	49.6	599	1	26	0
INSIDE RM 206	0	73.1	49.6	601	1	31	0
NEXT TO RM 224	0	74.1	48.9	581	1	32	0
NEXT TO SOUTH SIDE OF ROOM 217	0	74.6	52.1	586	1	29	0
NEXT TO ROOM 217	2	74.9	51.9	577	1	26	0
NEXT TO STAIRS #2 4th FLOOR	1	73.1	52.1	561	1	21	0
SOUTH END OF HALLWAY 2nd FLOOR	3	73.6	51.6	609	1	19	0
NORTH END OF 2nd FLOOR HALLWAY	0	73.5	50.3	610	1	28	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: 

Date: 6/24/02