

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 03-04-02

CLIENT: NYC BOE

PROJECT ADDRESS: H.S. for Leadership & Public Services (M894)
NY, NY

PROJECT NO: 41617-0561

SAMPLED BY: Y. Efstathiou

SAMPLE DATE: 03-01-02

DATE RECEIVED: 03-01-02

DATE ANALYZED: 03-01-02

SAMPLE MEDIA: Dust Wipe Sample

ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
01	9702	Blank	<9.0 μg	9.0 μg
02	9702	1st Floor Lobby (Floor)	<9.0	9.0
03	9702	Auditorium	<9.0	9.0
04	9702	Classroom #806	<9.0	9.0
05	9702	Classroom #403 Window Sill	<9.8	9.8
06	9702	3rd Floor Hallway (Floor)	<9.0	9.0
07	9702	5th Floor Hallway (Floor)	<9.0	9.0
08	9702	7th Floor Hallway (Floor)	<9.0	9.0
09	9702	9th Floor Hallway (Floor)	<9.0	9.0
10	9702	13th Floor Hallway (Floor)	<9.0	9.0
11	9702	Cafeteria	<9.0	9.0

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$,
Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.

NOTE 3:
Blank units are in μg

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: *HCU*

REPORT PREPARED BY: *[Signature]*

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: *[Signature]*

LABORATORY DIRECTOR: *[Signature]*

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).