

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 03-21-02

CLIENT: NYC BOE

PROJECT ADDRESS: (M894)/90 Trinity Place
NY, NY 10006

PROJECT NO: 41617-0561

SAMPLED BY: Y. Efstathiou

SAMPLE DATE: 03-21-02

DATE RECEIVED: 03-21-02

DATE ANALYZED: 03-21-02

SAMPLE MEDIA: Dust Wipe Sample

ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft²)	DETECTION LIMIT (µg/ft²)
01	9735	Blank	<9.0 µg	9.0 µg
02	9735	Cafeteria Floor	<9.0	9.0
03	9735	Auditorium Floor	<9.0	9.0
04	9735	Classroom 815 Floor	<9.0	9.0
05	9735	Classroom 503 Window Sill	<9.7	9.7
06	9735	3rd Floor Hallway Floor	<9.0	9.0
07	9735	5th Floor Hallway	<9.0	9.0
08	9735	7th Floor Hallway	<9.0	9.0
09	9735	9th Floor Hallway	<9.0	9.0
10	9735	13th Floor Hallway	<9.0	9.0
11	9735	1st Floor Lobby	<9.0	9.0

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: TL

REPORT PREPARED BY: J. Harte

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: W. Harte

LABORATORY DIRECTOR: M. Harte

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).