

ATC ASSOCIATES, INC.

Page 1 of 1

TIME 2:30 PM

INDOOR AIR QUALITY FIELD REPORT

(11894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE DATE 03/05/02 PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
MAIN ENTRANCE		49.8	21.1	365	2	79	0.0
NORTH OF MAIN ENTRANCE		46.9	21.5	349	5 ppm	72	0.0
SOUTH OF MAIN ENTRANCE		39.0	21.6	317	4	68	0.0
Hallway 14th Floor		57.8	30.9	535	0	44	0.0
KITCHEN 14 FL	3	62.2	30.4	550	0	23	0.0
STAIRWELL A Room #106	0	38.7	21.5	313	0	8	0.0
Hallway 3rd Floor	0	65.5	23.7	571	1	6	0
STAIRWELL 13th Floor A	3	66.3	22.5	547	1	10	0
12th Floor Hallway	15	67.6	23.6	711	1	15	0
Room #1206	4	68.0	23.3	702	1	10	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Frank DiddapainDate: 03/05/02

Page 3 of 3

TIME

(14894)

PROJECT NO. 19125-0290

Location	Occup.	Temperature (F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
Room #1003	1	70.4	20.6	669	2	18	0.0
Hallway By Elevators	1	70.7	20.3	622	1	15	0.0
Room #1009	0	70.6	19.5	549	1	7	0.0
Room #1015	3	70.8	20.1	654	1	9	0.0
Hallway 10th Floor	0	70.6	20.4	613	1	13	0.0
STAIRwell B 9th Floor	0	70.1	20.1	617	1	10	0.0
Hallway By Room #915	0	69.7	20.0	603	1	9	0.0
Room #915	0	69.5	19.8	605	1	8	0.0
Room #906	0	68.5	18.6	524	1	7	0.0
Room #903	1	69.4	18.8	531	1	7	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: Pranil Daddapuri Date: 23/05/22

ATC ASSOCIATES, INC.

Page 5 of 5

TIME _____

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICEPROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
Room # 703	0	69.5	19.4	515	1	6	0.0
Room # 705	4	70.4	20.6	645	1	10	0.0
Hallway 7th Floor Elev	2	70.4	20.2	657	1	5	0.0
Room # 702	3	70.2	20.3	680	1	12	0.0
STAIR A 7th Floor	0	70.1	20.1	600	1	8	0.0
Hallway 6th Floor Elev	1	69.1	20.9	611	2	6	0.0
Room # 609	1	70.1	20.1	541	2	5	0.0
Hallway		70.3	21.1	671	2	5	0.0
Room # 613	4	70.1	21.0	592	1	4	0.0
STAIR WALK B 6th Floor	0	69.9	20.1	538	1	5	0.0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Ravi Daddapani Date: 03/05/02

ATC ASSOCIATES, INC.

Page 6 of 6

TIME _____

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE DATE _____

PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
5th Floor Elev Hallway	0	68.9	19.6	553	2	9	0.0
Room # 415	0	69.3	18.9	467	1	6	0.0
4th Floor Hallway	0	70.3	19.2	510	1	5	0.0
Room # 404	0	69.5	19.1	489	1	5	0.0
Room # 409	2	70.0	19.1	485	1	4	0.0
Room # 403	12	70.1	21.2	705	1	7	0.0
STAIRWELL A 4th Floor	0	70.2	21.3	867	1	5	0.0
STAIRWELL A 3rd Floor	2	69.9	20.6	702	1	15	0.0
Room # 305	12	70.7	20.2	656	1	7	0.0
Hallway 3rd Floor	0	70.9	20.6	658	1	6	0.0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Frank DeLapina Date: 03/05/02

ATC ASSOCIATES, INC.

Page 7 of 7

TIME _____

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE DATE 03/05/02 PROJECT NO. 19125-0290

Location	Occup.	Temperature (F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Room #315	1	69.6	18.8	502	2	5	0.0
STARwell A 2nd Floor	2	69.8	20.4	639	2	4	0.0
Hallway 2nd floor	0	70.4	20.2	674	1	6	0.0
Room #206	0	71.3	19.6	784	1	6	0.0
Room #205	3	71.3	19.5	593	1	8	0.0
Hallway 3rd fl	0	67.9	31.1	709	2	22	0.0
3rd fl Gym	10	70.6	31.3	891	2	18	0.0
MAIN ENTRANCE		44.2	16.6	355	4	52	0.0
NORTH OF MAIN ENTRANCE		45.6	16.9	359	4	49	0.0
SOUTH OF MAIN ENTRANCE		45.3	17.8	365	3	33	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Ross A. Deddaphan Date: 03/05/02