

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 4/24/02 8:40:00 PM
 ATC Group #: 7523
 Analysis Date: 4/24/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE PS 234M Project#: 14584-1823
 292 Greenwich St., New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5 μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
01 7523 -1	1928.00	0.0450	0	None Detected	0	0	0.0044 <22.24 <0.0044	
02 7523 -2	1936.00	0.0450	0	None Detected	0	0	0.0044 <22.24 <0.0044	
03 7523 -3	1936.00	0.0450	0	None Detected	0	0	0.0044 <22.24 <0.0044	
04 7523 -4	1928.00	0.0450	0	None Detected	0	0	0.0044 <22.24 <0.0044	
05 7523 -5	1928.00	0.0450	0	None Detected	0	0	0.0044 <22.24 <0.0044	
06 7523 -6	1936.00	0.0450	0	None Detected	0	0	0.0044 <22.24 <0.0044	
07 7523 -7	1936.00	0.0450	0	None Detected	0	0	0.0044 <22.24 <0.0044	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 4/24/02 8:40:00 PM
ATC Group #: 7523
Analysis Date: 4/24/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE PS 234M Project#: 14584-1823
292 Greenwich St., New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
08 7523 -8	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
09 7523 -9	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
10 7523 -10	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
11 7523 -11	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
12 7523 -12	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
13 7523 -13	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
14 7523 -14	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
15 7523 -15	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879