

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 6TIME 1400LOCATION PS 234 M DATE 4/18/02 PROJECT NO. 19125-279

Location	Occup:	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Outside							
SW Corner		83.5	50.4	478	3	36	0
South Side		83.7	50.6	470	3	38	0
West Side		84.0	50.9	468	3	35	0
NW Corner		84.2	51.3	471	3	39	0
Courtyard		84.5	51.5	473	3	34	0
NE Corner		84.3	51.9	476	3	30	0
Main Entrance		84.6	52.1	480	3	33	0
SE Corner		84.9	52.5	478	3	36	0
Main Entrance		80.5	43.1	528	3	50	0
Inside by Main Desk		78.2	45.3	683	3	34	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jim Chen Date: 4/18/02

CITY_21MC100_002851771

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 6TIME 1430LOCATION PS 234 M DATE 4/18/02 PROJECT NO. 19125 - 279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Main Foyer.		78.6	43.8	798	3	32	0
Main Desk	5	78.6	42.4	780	3	33	0
Cafeteria.		77.6	42.7	785	3	29	0
Hall by Gym	-	77.2	43.0	769	3	35	0
Gym	-	77.0	42.8	791	3	34	0
Hall by Elevator	-	76.3	43.4	762	3	36	0
Hall by Exit 1		75.7	43.3	703	3	33	0
114 (Hall)		74.6	43.6	752	3	32	0
116		74.1	43.0	716	3	29	0
118	20	73.5	43.5	801	3	28	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jim Chen Date: 4/18/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6


TIME 1500

LOCATION PS 234 M DATE 4/18/02 PROJECT NO. 19125 - 279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
120	26	73.7	45.9	852	3	36	0
122 (Hall)		74.0	47.8	803	3	35	0
122		73.5	44.8	810	3	32	0
Hall by Stair 3		73.8	47.5	820	3	30	0
222		73.6	45.6	788	3	29	0
220		73.8	44.0	826	3	31	0
218		73.0	44.3	820	3	32	0
216		72.9/	44.6	796	3	36	0
216 (Hall)		73.6	47.6	801	3	30	0
227 (Hall)		73.4	47.5	790	3	29	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 4/18/02

CITY_21MC100_002851773

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 6TIME 1530LOCATION PS 234 M DATE 4/18/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
229		73.8	47.3	777	2	33	0
225		74.1	46.8	769	2	30	0
210		73.6	47.6	709	3	34	0
Hall by Stair ¹ _A		74.0	46.7	801	3	38	0
223		73.4	44.0	751	2	29	0
219		73.2	44.5	755	3	30	0
215		72.9	44.9	888	3	31	0
206		74.0	45.0	709	3	34	0
206 (Hall)		73.9	46.6	799	3	36	0
Hall by Stair ² _A		73.6	46.8	790	3	34	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jig Chen Date: 4/18/02

CITY_21MC100_002851774


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6TIME 15:45
4:00LOCATION PS 234 M DATE 4/18/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
201		72.0	47.0	700	3	28	0
202		71.8	47.3	690	3	30	0
301		72.3	46.8	699	3	32	0
302		72.6	46.5	701	3	30	0
Hall by 302		73.1	48.0	809	3	35	0
304		73.5	46.1	709	3	29	0
305		73.9	44.0	719	3	30	0
306		73.5	45.3	720	3	19	0
311		73.0	45.8	729	3	28	0
315		72.9	44.4	735	3	26	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 4/18/02

CITY_21MC100_002851775

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6TIME 1600LOCATION PS 234 MDATE 4/18/02PROJECT NO. 19125 - 279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
308		73.8	46.3	700	2	26	0
319		73.6	47.0	698	2	20	0
323		74.0	46.8	709	2	19	0
310		72.9 ✓	46.5	715	2	23	0
325		73.6	46.0	729	2	26	0
329		73.8	45.7	608	2	30	0
316		73.6	46.1	611	2	32	0
318		73.1	46.3	651	2	30	0
320		72.8	44.0	750	2	18	0
322		72.6 /	43.8	759	2	30	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: _____ Date: 4/18/02

CITY_21MC100_002851776